STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Rolland W. Redlin

Address 1005 21st. N.W. Minot N. Dak

2. WELL LOCATION 58703 701-838-4791

Sketch map location must agree with written location.

NORTH

1 Mile

Sec. [1 Mile] _____

County DIVIDE

____ ¼ WN ¼ NW ¼ Sec. 29 Twp. 161 N. Rg. 97 W.

3. PROPOSED USE

☐ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for chemical analysis?

☒ Yes ☐ No

If so, to what laboratory was it sent _____

6. WELL CONSTRUCTION

Diameter of hole 9 inches. Depth 200 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft.	5 inches	0 feet	180 feet
____ lb/ft.	____ inches	____ feet	____ feet
____ lb/ft.	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No

Perforated pipe set from ____ ft to ____ feet

Was casing left open end? ☒ Yes ☐ No

Was a well screened installed? ☒ Yes ☐ No

Material PVC Diameter 5 inches
(stainless steel, bronze, etc.)

Slot size 30 set from 180 feet to 200 feet

Slot size ____ set from ____ feet to ____ feet

Was a packer or seal used? ☐ Yes ☐ No

If so, what material ____ Depth ____ Ft.

Type of well: Straight screen ☒ Gravel packed ☐

Depth grouted: From 0 To 90

Grouting Material: Cement ____ Other Enviro Plug

If other explain: _____

Well head completion: Pitless unit yes

12" above grade yes Other _____

If other, specify _____

Was pump installed: ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 82 feet below land surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other Air

Pumping level below land surface:

160 ft. after 2 hrs. pumping 60 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top Soil	0	1
Glacial Till	1	130
Sands & Gravel	130	200

(Use separate sheet if necessary.)

10. DATE COMPLETED 6-14-00

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Mark Adair Drilling 194
Driller's or Firm's Name Certificate No.

#12 Nichols Rd. Box 525 Plentywood mt 59254
Address

Mark Adair 6-14-00
Signed by Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY