STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name JORDEN KRECKLAU

Address WOONAN ND

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) ____ DIVIDE

County

SW 1/4 SE 1/4 SW 1/4 Sec. 3 Twp. 162 N.Rg 96 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☐ Yes ☒ No

If so, to what laboratory was it sent? OWNER SAMPLING

6. WELL CONSTRUCTION

Diameter of hole 8 3/4 inches. Depth 51 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
SDR 21 lb/ft	5 inches	0 feet	46 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 46 ft to 51 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screened installed? ☒ Yes ☐ No

Material PLASTIC Diameter 5 inches

Slot Size .32 set from 46 feet to 51 feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material ____ Depth ____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 10 To 40

Grouting Material: Cement ____ Other X

If other explain: BENTONITE PELLETS

Well head completion: Pitless unit ____

12" above grade X Other ____

If other, specify OWNER COMPLETING

Was pump installed: ☐ Yes ☒ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 40 feet below surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

46 ft. after 2 hrs. pumping 8 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
SURFACE	0	1
BROWN CLAY	1	23
GRAY CLAY	23	46
SAND	46	51
GRAY CLAY	51	60

(Use separate sheet if necessary)

10. DATE COMPLETED 9-20-98

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

KROSHUS DRILLING 193

Driller's or Firm's Name Certificate No

BOX 434 CROSBY, ND 58730

Address

Robert Kroshus 9-20-98

Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY