STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name ARDEN THOMPSON

Address RURAL CROSBY ND

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

County DIVIDE

SE ¼ SE ¼ SE ¼ Sec. 7 Twp. 162 N.Rg 96 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☐ Yes ☒ No

If so, to what laboratory was it sent? OWNER SAMPLING

6. WELL CONSTRUCTION

Diameter of hole 8 3/4 inches. Depth 110 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
SDR21 lb/ft	5 inches	0 feet	99 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 99 ft to 109 feet

Was casing left open end? ☒ Yes ☐ No

Was a well screened installed? ☒ Yes ☐ No

Material PLASTIC Diameter 5 inches

Slot Size .032 set from 99 feet to 109 feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 20 To 40

Grouting Material: Cement _____ Other X

If other explain: BENTONITE PELLETS

Well head completion: Pitless unit _____

12" above grade X Other _____

If other, specify OWNER COMPLETING

Was pump installed: ☐ Yes ☒ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 34 feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

46 ft. after 3 hrs. pumping 10 gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
SURFACE	0	1
BROWN CLAY	1	24
GRAY CLAY	24	71
COARSE SAND AND GRAVEL	71	110

(Use separate sheet if necessary)

10. DATE COMPLETED 10-15-97

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

KROSHUS DRILLING — Driller's or Firm's Name

193 — Certificate No

BOX 434 CROSBY, ND — Address

58730

Robert Kroshus — Signed by

10-16-97 — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY