STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Edward E Schmidt

Address HC1 Box 9 Hazelton, N.D.

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) ____

County Emmons

____ 1/4 ____ 1/4 NW 1/4 Sec. 36 Twp. 136 N.Rg 78 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify ____

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☐ Yes ☐ No

If so, to what laboratory was it sent? ____

6. WELL CONSTRUCTION

Diameter of hole 7 inches. Depth 142 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify ____

Pipe Weight:	Diameter:	From:	To:
____ lb/ft	4 inches	2 feet	142 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 122 ft to 142 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screened installed? ☐ Yes ☒ No

Material ____ Diameter ____ inches

Slot Size ____ set from ____ feet to ____ feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material ____ Depth ____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 0 To 20

Grouting Material: Cement X Other ____

If other explain: ____

Well head completion: Pitless unit ____

12" above grade 24" Other ____

If other, specify ____

Was pump installed: ☐ Yes ☒ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 40 feet below surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify ____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

42 ft. after 1 hrs. pumping 11 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Black dirt	0	1
gray Clay	1	118
rock	118	120
Blue sand	120	142
hard rock	142	

(Use separate sheet if necessary)

10. DATE COMPLETED 6-1-95

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how ____

12. REMARKS:

Edward E Schmidt 6-1-95
will have water tested

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Witko Drilling 149

Driller's or Firm's Name — Certificate No

510 3rd ave NE Mandan N.D.

Address

Kasper Witko 6-1-95

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY