STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: DENNIS GABRIEL

Address: NORTHWOOD, N.D. 58267

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH



Sec. (1 mile) _____

County: GRAND FORKS

SE ¼ NE ¼ NE ¼ Sec. 9 Twp. 149 N. Rg 54 W.

3. PROPOSED USE

☐ Domestic ☐ Stock ☒ Irrigation (LAWN WATERING) ☐ Municipal ☐ Geothermal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☐ Yes ☒ No

If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION

Diameter of hole 5 inches. Depth 45 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
220 lb/ft	4 inches	0 feet	35 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☐ Yes ☒ No

Perforated pipe set from _____ ft to _____ feet

Was casing left open end? ☐ Yes ☒ No

Was a well screened installed? ☒ Yes ☐ No

Material PLASTIC Diameter 4 inches

Slot Size .012 set from 35 feet to 45 feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 0 To 20

Grouting Material: Cement X Other _____

If other explain: _____

Well head completion: Pitless unit _____

12" above grade X Other _____

If other, specify _____

Was pump installed: ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 9'-6" feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

15-0 ft. after 1 hrs. pumping 20 gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
BLACK DIRT	0	3
YELLOW CLAY	3	12
GREY SILT	12	30
FINE GREY SAND	30	45

(Use separate sheet if necessary)

10. DATE COMPLETED 5-21-94

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

EARTHENERGY SYSTEMS 138

Driller's or Firm's Name Certificate No

NORTHWOOD, N.D. 58267

Address

Reuben A. Medved

Signed by Date 8-30-94

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY