STATE OF NORTH DAKOTA

# BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

# WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

**1. WELL OWNER**

Name: Robert Anderson

Address: Minnewaukan N.Dak.

**2. WELL LOCATION**

Sketch map location must agree with written location.




County: Benson Co.

NE ¼ NE ¼ SW ¼ Sec. 32 Twp. 153 N. Rg. 67 W.

**3. PROPOSED USE**

☐ Domestic ☐ Irrigation ☐ Industrial
☒ Stock ☐ Municipal ☐ Test Hole

**4. METHOD DRILLED**

☐ Cable ☐ Reverse Rotary ☒ Bored
☐ Forward Rotary ☐ Jetted ☐ Other

If other, specify _____

**5. WATER QUALITY**

Was a water sample collected for chemical analysis?

☐ Yes ☒ No

If so, to what laboratory was it sent _____

**6. WELL CONSTRUCTION**

Diameter of hole 36 inches. Depth 26 feet.

Casing: ☒ Steel ☐ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify _____

| Pipe Weight: | Diameter: | From: | To: |
|---|---|---|---|
| 33.38 lb/ft. | 12 inches | +1 feet | 22 feet |
| lb/ft. | inches | feet | feet |
| lb/ft. | inches | feet | feet |
| lb/ft. | inches | feet | feet |

Was perforated pipe used? ☐ Yes ☒ No

Length of pipe perforated _____ feet

Was casing left open end? ☒ Yes ☐ No

Was a well screened installed? ☒ Yes ☐ No

Material: Low Carbon (stainless steel, bronze, etc.) Diameter 12 inches

Slot size 50 set from 22 feet to 26 feet

Slot size _____ set from _____ feet to _____ feet

Slot size _____ set from _____ feet to _____ feet

Slot size _____ set from _____ feet to _____ feet

Was a packer or seal used? ☐ Yes ☒ No

If so, what material _____

Type of well: Straight screen ☐ Gravel packed ☒

Was the well grouted? Yes ☒ No ☐

To what depth? 10 feet

Material used in grouting Cement + Clay

Well head completion: Pitless adapter _____

12" above grade Yes Other _____

If other, specify _____

Was well disinfected upon completion? ☒ Yes ☐ No

**7. WATER LEVEL**

Static water level 10 feet below land surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

**8. WELL TEST DATA**

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

**9. WELL LOG**

| Formation | Depth (ft.) From | Depth (ft.) To |
|---|---|---|
| Topsoil | 0 | 1 |
| Yellow Clay | 1 | 15 |
| Blue Clay | 15 | 19 |
| Blue Sand & Gravel | 19 | |
| Fine & Coarse with Boulders | | 26 |

(Use separate sheet if necessary.)

**10. DATE COMPLETED** 9/29/77

**11. WAS WELL PLUGGED OR ABANDONED?**

☐ Yes ☒ No

If so, how _____

**12. REMARKS:**

**13. DRILLER'S CERTIFICATION**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Central City Well Boring — 87

Driller's or Firm's Name — Certificate No.

Carrington N.Dak.

Address

Robert L. Bird — 9/29/77

Signed by — Date

DUPLICATE — BOARD'S COPY