STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Gordon Etter

Address Wimbledon N Dak

2. WELL LOCATION

Sketch map location must agree with written location.

#2-6"

NORTH

1 Mile

County Barnes

SE ¼ SE ¼ NE ¼ Sec. 26 Twp. 143 N. Rg. 61 W.

3. PROPOSED USE

☐ Domestic ☐ Geothermal ☑ Irrigation ☐ Industrial ☐ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored ☑ Forward Rotary ☐ Jetted ☐ Other

If other, specify

5. WATER QUALITY

Was a water sample collected for chemical analysis?

☐ Yes ☑ No

If so, to what laboratory was it sent

6. WELL CONSTRUCTION

Diameter of hole 10 inches. Depth 43 feet.

Casing: ☑ Steel ☐ Plastic ☐ Concrete ☐ Threaded ☑ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
.250 lb/ft.	6 inches	+2 feet	33 feet
lb/ft.	inches	feet	feet
lb/ft.	inches	feet	feet
lb/ft.	inches	feet	feet

Was perforated pipe used? ☐ Yes ☑ No

Length of pipe perforated feet

Was casing left open end? ☐ Yes ☑ No

Was a well screened installed? ☑ Yes ☐ No

Material Stainless steel (stainless steel, bronze, etc.) Diameter 6 inches

Slot size 100 set from 33 feet to 43 feet

Slot size set from feet to feet

Slot size set from feet to feet

Slot size set from feet to feet

Was a packer or seal used? ☐ Yes ☑ No

If so, what material

Type of well: Straight screen ☐ Gravel packed ☑

Was the well grouted? Yes ☑ No ☐

To what depth? 10 feet

Material used in grouting Cement

Well head completion: Pitless adapter

12" above grade yes Other ✓

If other, specify well seal

Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL

Static water level 14'6" feet below land surface

If flowing: closed-in pressure psi

GPM flow through inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

ft. after hrs. pumping gpm

ft. after hrs. pumping gpm

ft. after hrs. pumping gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Brown clay & cobbles	0	17
Gray hard clay	17	30
med to coarse sand fairly clean	30	43
Gray silty clay	43	47
Rock	47	

(Use separate sheet if necessary.)

10. DATE COMPLETED Feb 13 1984

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☑ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Traut Well Drilling 85

Driller's or Firm's Name Certificate No.

933 17th St. SW

Address

Jamestown N Dak.

Signed by Gordon Domke Date Feb 14-84

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY