STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Larry Petty

Address Kintyre, ND.

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

County Logan Sec. (1 mile) ____

____ 1/4 ____ 1/4 S 1/4 Sec. 7 Twp. 133 N.Rg 73 W.

3. PROPOSED USE

☐ Domestic ☐ Geothermal ☐ Monitoring
☑ Stock ☐ Irrigation ☐ Industrial
☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☑ Cable ☐ Reverse Rotary ☐ Bored
☐ Forward Rotary ☐ Jetted ☐ Auger

If other, specify ____

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☐ Yes ☑ No

Bacteriological Analysis? ☐ Yes ☐ No

If so, to what laboratory was it sent? ____

6. WELL CONSTRUCTION

Diameter of hole 6 inches. Depth 180 feet.

Casing: ☐ Steel ☑ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify ____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	4 inches	0 feet	180 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☑ Yes ☐ No

Perforated pipe set from 160 ft to 180 feet

Was casing left open end? ☑ Yes ☐ No

Was a well screened installed? ☐ Yes ☑ No

Material ____ Diameter ____ inches

Slot Size ____ set from ____ feet to ____ feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☐ Yes ☑ No

If so, what material ____ Depth ____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☑

Depth grouted: From 0 To 12

Grouting Material: Cement ____ Other ____

If other explain: Ready mix

Well head completion: Pitless unit ____

12" above grade ____ Other ____

If other, specify ____

Was pump installed: ☑ Yes ☐ No

Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL

Static water level 100 feet below surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify ____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☑ Other

Pumping level below land surface:

140 ft. after 1 hrs. pumping 10 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Light brown clay	0	140
Blue clay	140	165
Blue clay & blue sand	165	180

(Use separate sheet if necessary)

10. DATE COMPLETED Sept 20, 1996

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☐ No

If so, how ____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Grow Drilling — 66

Driller's or Firm's Name — Certificate No

Napoleon, ND — 58561

Address

Clemen Grow — Sept 23, 1996

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY