STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Arthur Meidinger

Address: 89 20 26 Ave SE Zeeland ND. 58581

2. WELL LOCATION

Sketch map location must agree with written location.



County: McIntosh

___ ¼ SW ¼ NW ¼ Sec. 23 Twp. 131 N. Rg. 73 W.

3. PROPOSED USE

☐ Geothermal
☑ Domestic ☐ Irrigation ☐ Industrial
☐ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☑ Bored
☐ Forward Rotary ☐ Jetted ☐ Other

If other, specify ____

5. WATER QUALITY

Was a water sample collected for chemical analysis?

☐ Yes ☑ No Another contractor hooked up well

If so, to what laboratory was it sent ____

6. WELL CONSTRUCTION

Diameter of hole 28" inches. Depth 56' feet.

Casing: ☑ Steel ☐ Plastic ☑ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify ____

Pipe Weight:	Diameter:	From:	To:
80. lb/ft.	20" inches	10' feet	56' feet
14.92 lb/ft.	5" I.D. inches	8' feet	10½' feet
___ lb/ft.	___ inches	___ feet	___ feet
___ lb/ft.	___ inches	___ feet	___ feet

Was perforated pipe used? ☐ Yes ☑ No

Length of pipe perforated ____ feet

Was casing left open end? ☑ Yes ☐ No

Was a well screened installed? ☐ Yes ☑ No

Material Haydite Concrete tile Diameter 20" inches
(stainless steel, bronze, etc.)

Slot size ____ set from ____ feet to ____ feet
Slot size ____ set from ____ feet to ____ feet
Slot size ____ set from ____ feet to ____ feet
Slot size ____ set from ____ feet to ____ feet

Was a packer or seal used? ☐ Yes ☑ No

If so, what material ____

Type of well: Straight screen ☐ Gravel packed ☑

Was the well grouted? Yes ☑ No ☐

To what depth? 9' to 30' feet

Material used in grouting Neat Cement & granular Bentonite

Well head completion: Pitless adapter Minitor 5" x 7"

12" above grade 6" Steel Other ____

If other, specify ____

Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL

Static water level ____ feet below land surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify ____

8. WELL TEST DATA

☐ Pump ☑ Bailer ☐ Other

Pumping level below land surface:

52' ft. after 2 hrs. pumping 18 gpm
___ ft. after ___ hrs. pumping ___ gpm
___ ft. after ___ hrs. pumping ___ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Topsoil	0	1
Light Brown sandy clay	1	5
Fine to Course light brown sand	5	30'
Light brown-blonde sand to sandy clay	30	48'
Gray-blue clay w/sand stringers	48	54'
Gray-blue clay	54'	56'

(Use separate sheet if necessary.)

10. DATE COMPLETED 8-15-97

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☑ No

If so, how ____

12. REMARKS: Well will be hooked up to house in yard.

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Allied Well Service — # 111
Driller's or Firm's Name — Certificate No.

Hebridge S. Dak.
Address

Jerome Abeele
Signed by — Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY