STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Eddy Norby

Address Rt 1 Watford City ND 58854

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH



1 Mile

152
96

County McKenzie Co.

SE ¼ SE ¼ SE ¼ Sec. 2 Twp. 153 N. Rg. ___ W.

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Industrial
☐ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored
☒ Forward Rotary ☐ Jetted ☐ Other

If other, specify ___

5. WATER QUALITY

Was a water sample collected for chemical analysis?

☐ Yes ☒ No

If so, to what laboratory was it sent ___

6. WELL CONSTRUCTION

Diameter of hole 8 3/4 inches. Depth 138 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify ___

Pipe Weight:	Diameter:	From:	To:
200 lb/ft.	4 inches	0 feet	138 feet
___ lb/ft.	___ inches	___ feet	___ feet
___ lb/ft.	___ inches	___ feet	___ feet
___ lb/ft.	___ inches	___ feet	___ feet
___ lb/ft.	___ inches	___ feet	___ feet

Was perforated pipe used? ☒ Yes ☐ No

Length of pipe perforated 10 ft feet

Was casing left open end? ☒ Yes ☐ No

Was a well screened installed? ☐ Yes ☒ No

Material ___ Diameter ___ inches
(stainless steel, bronze, etc.)

Slot size ___ set from ___ feet to ___ feet
Slot size ___ set from ___ feet to ___ feet
Slot size ___ set from ___ feet to ___ feet
Slot size ___ set from ___ feet to ___ feet

Was a packer or seal used? ☐ Yes ☒ No

If so, what material ___

Type of well: Straight screen ☐ Gravel packed ☒

Was the well grouted? Yes ☒ No ☐

To what depth? 1 feet

Material used in grouting quick crete

Well head completion: Pitless adapter ___

12" above grade ___ Other ___

If other, specify ___

Was well disinfected upon completion? ☐ Yes ☒ No

7. WATER LEVEL

Static water level 108 feet below land surface

If flowing: closed-in pressure ___ psi

GPM flow 7 through 1 inch pipe

Controlled by: ☒ Valve ☐ Reducers ☐ Other

If other, specify ___

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

130 ft. after 5 hrs. pumping 7 gpm
___ ft. after ___ hrs. pumping ___ gpm
___ ft. after ___ hrs. pumping ___ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Brown sand	0	5
gray clay	5	10
Gray clay	10	15
Gray clay	15	20
Gray clay	20	25
Blue clay	25	105
Blue sand & clay	105	135
Blue sand & fine gravel	135	138

(Use separate sheet if necessary.)

10. DATE COMPLETED 10-1-82

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how ___

12. REMARKS: Well wasn't disinfected the well is to be completed by the owner.

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Bryant Kenner 196
Driller's or Firm's Name Certificate No.

Watford City N.D.
Address

Bryant Kenner 10-4-82
Signed by Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY