STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Robert Chrusych

Address 2224 130th Ave SW

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) ____

County Billings

NE 1/4 NW 1/4 SE 1/4 Sec. 29 Twp. 142 N.Rg 99 W.

3. PROPOSED USE

☐ Domestic ☐ Geothermal ☐ Monitoring
☐ Stock ☐ Irrigation ☐ Industrial
☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☒ Bored
☐ Forward Rotary ☐ Jetted ☐ Auger

If other, specify ____

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☒ Yes ☐ No

Bacteriological Analysis? ☐ Yes ☐ No

If so, to what laboratory was it sent? ____

6. WELL CONSTRUCTION

Diameter of hole 18 inches. Depth 37 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify ____

Pipe Weight:	Diameter:	From:	To:
210 lb/ft	5 inches	1 feet	37 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 26 ft to 37 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screened installed? ☐ Yes ☒ No

Material ____ Diameter ____ inches

Slot Size ____ set from ____ feet to ____ feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☐ Yes ☐ No

If so, what material ____ Depth ____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 0 To 19

Grouting Material: Cement ____ Other ____

If other explain: ____

Well head completion: Pitless unit ____

12" above grade ____ Other ____

If other, specify ____

Was pump installed: ☐ Yes ☒ No

Was well disinfected upon completion? ☐ Yes ☒ No

7. WATER LEVEL

Static water level 16 feet below surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify ____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

39 ft. after 1 hrs. pumping 20 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top soil	0	1'
Yellow Clay	1'	10'
Brown and [redacted]	10'	19'
Gray sand fine	19'	25'
Gray sand medium with		
Brown sand	25'	34'
Dark sand fine & Coa	34'	37'

(Use separate sheet if necessary)

10. DATE COMPLETED 7-24-2000

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how ____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Lewis & Mahoney #140

Driller's or Firm's Name Certificate No

Box 904 Belfield ND 58622

Address

Lewis & Mahoney 7-24-2000

Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY