STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

DEC 1990 RECEIVED State Water Commission

1. WELL OWNER

Name: Harvey Billadeau

Address: Ryan, N.D.

2. WELL LOCATION

Sketch map location must agree with written location.



County: McLean

NE ¼ NW ¼ NW ¼ Sec. 9 Twp. 149 N. Rg. 89 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☐ Yes ☒ No

If so, to what laboratory was it sent

6. WELL CONSTRUCTION

Diameter of hole 5/8 inches. Depth 206 feet. 1318

Casing: ☒ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
P.V.C. lb/ft.	5 inches	0 feet	206 feet
3.75 lb/ft.	2 inches	0 feet	1318 feet
lb/ft.	inches	feet	feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 1268 ft to 1318 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screened installed? ☐ Yes ☐ No

Material _____ Diameter _____ inches
(stainless steel, bronze, etc.)

Slot size _____ set from _____ feet to _____ feet

Slot size _____ set from _____ feet to _____ feet

Was a packer or seal used? ☐ Yes ☐ No

If so, what material _____ Depth _____ Ft.

Type of well: Straight screen ☐ Gravel packed ☐

Depth grouted: From 170 To 740

Grouting Material: Cement X Other

If other explain:

Well head completion: Pitless unit

12" above grade X Other

If other, specify

Was pump installed: ☐ Yes ☒ No

Was well disinfected upon completion? ☐ Yes ☒ No

7. WATER LEVEL

Static water level _____ feet below land surface

If flowing: closed-in pressure 37 psi

GPM flow 9.5 through 2 inch pipe

Controlled by: ☒ Valve ☒ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
topsoil	0	2
Gravel	2	11
Buff clay	11	26
Lignite	26	28
Gray clay	28	51
Lignite	51	52
Gray clay	52	131
Lignite	131	133
Gray clay	133	452
Lignite	452	456
Gray clay	456	641
Sandy clay	641	676
Gray clay	676	1272
Sand	1272	1318
clay	1318	—

(Use separate sheet if necessary.)

10. DATE COMPLETED 12-1-90

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Mann-Stimpfl Drilling 52

Driller's or Firm's Name — Certificate No.

RR1 Box 44 Colehar Bar, N.D. 58531

Address

David Stimpfl 12-1-90

Signed by — Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY