STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Donald Nishek

Address Box 9973 8th Ave. SE Elendale, ND

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

X

Sec. (1 mile) ____

County Dickey

____ ¼ SE ¼ SE ¼ Sec. 21 Twp. 129 N.Rg 63 W.

3. PROPOSED USE

☐ Geothermal ☐ Monitoring
☒ Domestic ☐ Irrigation ☐ Industrial
☒ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored
☒ Forward Rotary ☐ Jetted ☐ Auger

If other, specify ____

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☒ Yes ☐ No

Bacteriological Analysis? ☒ Yes ☐ No

If so, to what laboratory was it sent? Bismark, ND

6. WELL CONSTRUCTION

Diameter of hole 8"-5" inches. Depth 1470 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify ____

Pipe Weight:	Diameter:	From:	To:
250 lb/ft	5 inches	0 feet	200 feet
80 lb/ft	2½ inches	0 feet	1390 feet
80 lb/ft	2½ inches	1390 feet	1470 feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 1390 ft to 1470 feet

Was casing left open end? ☒ Yes ☐ No

Was a well screened installed? ☐ Yes ☐ No

Material ____ Diameter ____ inches

Slot Size ____ set from ____ feet to ____ feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☒ Yes ☐ No

If so, what material Rubber Depth 1390 ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☐

Depth grouted: From 0 To 200

Grouting Material: Cement X Other ____

If other explain: ____

Well head completion: Pitless unit ____

12" above grade ____ Other ____

If other, specify ____

Was pump installed: ☐ Yes ☒ No

Was well disinfected upon completion? ☐ Yes ☒ No

7. WATER LEVEL

Static water level ____ feet below surface

If flowing: closed-in pressure 80 psi

GPM flow 125 through 2½ inch pipe

Controlled by: ☒ Valve ☐ Reducers ☐ Other

If other, specify ____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top soil	0	2
Yellow clay	2	15
Blue clay	15	40
Sand	40	45
Shale	45	750
Greenhorn	750	770
Shale	770	1160
Dakota	1160	1470

(Use separate sheet if necessary)

10. DATE COMPLETED 7-24-02

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how ____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Huron Drilling Inc. 127

Driller's or Firm's Name Certificate No

446 Custer Ave NE Huron, SD 57350

Address

7-24-02

Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY