STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Mike Meyer

Address Sulem

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) ____

County Morton

___ 1/4 NW 1/4 SE 1/4 Sec. 29 Twp. 133 N.Rg 82 W.

3. PROPOSED USE

☐ Domestic ☐ Geothermal ☐ Monitoring
☐ Stock ☐ Irrigation ☐ Industrial
☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored
☒ Forward Rotary ☐ Jetted ☐ Auger

If other, specify ____

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☐ Yes ☐ No

Bacteriological Analysis? ☐ Yes ☒ No

If so, to what laboratory was it sent? ____

6. WELL CONSTRUCTION

Diameter of hole 7 7/8 inches. Depth 162 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify P.V.C

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	4 inches	+2 feet	142 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☐ No

Perforated pipe set from ____ ft to ____ feet

Was casing left open end? ☒ Yes ☐ No

Was a well screened installed? ☒ Yes ☐ No

Material PVC Diameter 4 inches

Slot Size 016 set from 142 feet to 162 feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☐ Yes ☐ No

If so, what material ____ Depth ____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 10 To 80

Grouting Material: Cement ____ Other ____

If other explain: ____

Well head completion: Pitless unit ____

12" above grade ____ Other ____

If other, specify ____

Was pump installed: ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level ____ feet below surface

If flowing: closed-in pressure 5 psi

GPM flow 6 through 3/4 inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify ____

8. WELL TEST DATA

☐ Pump ☒ Bailer ☐ Other

Pumping level below land surface:

18 ft. after 2 hrs. pumping 12 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Loam	0	3
Loam + Sand	3	18
Clay & some sand	18	42
Mostly clay	42	84
clay	84	140
Blue sand	140	163

(Use separate sheet if necessary)

10. DATE COMPLETED Aug 19-97

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☐ No

If so, how ____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Joe Hartman 88

Driller's or Firm's Name Certificate No

P.O. Box 484 Mobridge S.D.

Address

Joe Hartman 9-17-97

Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY