STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: DAVE COOK

Address: 605 BROADWAY ST. LISBON ND

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 Mile

County: RANSOM

___ ¼ ___ ¼ BW ¼ Sec. 11 Twp. 134 N. Rg. 56 W.

3. PROPOSED USE

☐ Domestic ☐ Stock ☐ Geothermal ☑ Irrigation YARD ☐ Municipal ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored ☑ Forward Rotary ☐ Jetted ☐ Other

If other, specify ___

5. WATER QUALITY

Was a water sample collected for chemical analysis?

☐ Yes ☑ No

If so, to what laboratory was it sent ___

6. WELL CONSTRUCTION

Diameter of hole 6 3/4 inches. Depth 38 feet.

Casing: ☐ Steel ☐ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify ___

Pipe Weight:	Diameter:	From:	To:
200 lb/ft.	4 inches	0 feet	___ feet
___ lb/ft.	___ inches	___ feet	___ feet
___ lb/ft.	___ inches	___ feet	___ feet
___ lb/ft.	___ inches	___ feet	___ feet

Was perforated pipe used? ☑ Yes ☐ No

Length of pipe perforated 7 feet

Was casing left open end? ☐ Yes ☑ No

Was a well screened installed? ☐ Yes ☐ No

Material ___ Diameter ___ inches
(stainless steel, bronze, etc.)

Slot size ___ set from ___ feet to ___ feet

Slot size ___ set from ___ feet to ___ feet

Slot size ___ set from ___ feet to ___ feet

Slot size ___ set from ___ feet to ___ feet

Was a packer or seal used? ☐ Yes ☐ No

If so, what material ___

Type of well: Straight screen ☐ Gravel packed ☑

Was the well grouted? Yes ☑ No ☐

To what depth? 18 feet

Material used in grouting Neat Cement

Well head completion: Pitless adapter ___

12" above grade X Other ___

If other, specify ___

Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL

Static water level 12 feet below land surface

If flowing: closed-in pressure ___ psi

GPM flow ___ through ___ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify ___

8. WELL TEST DATA

☑ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

20 ft. after 10 hrs. pumping 15 gpm

___ ft. after ___ hrs. pumping ___ gpm

___ ft. after ___ hrs. pumping ___ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
top Soil	0	2
Dark clay	2	25
Gray Clay	20	25
Sand	25	26
Blue Clay	26	32
Coarse Sand	32	38
St Clay	38	

(Use separate sheet if necessary.)

10. DATE COMPLETED 5-2088

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☑ No

If so, how ___

12. REMARKS:

well East of House
4 ft. used to water

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Reckers Well Drilling 99

Driller's or Firm's Name — Certificate No.

RR 1 Box 21 Lisbon N.D.

Address

Robert Recker 5-3-88

Signed by — Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY