STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Arthur T. Krein

Address: RR1 Box 193 8776 34½ ST. S.E

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) ____

County: STUTSMAN

NE ¼ ___ ¼ ___ ¼ Sec. 22 Twp. 140 (Bloom) N. Rg 63 W.

3. PROPOSED USE

☒ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☒ Cable ☐ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify ____

5. WATER QUALITY

Was a water sample collected for:
Chemcial Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☐ Yes ☐ No
If so, to what laboratory was it sent? ____

6. WELL CONSTRUCTION

Diameter of hole 4 inches. Depth 100 feet.

Casing: ☒ Steel ☐ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify ____

Pipe Weight:	Diameter:	From:	To:
11 lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No
Perforated pipe set from ____ ft to ____ feet
Was casing left open end? ☒ Yes ☐ No
Was a well screened installed? ☐ Yes ☒ No
Material ____ Diameter ____ inches
Slot Size ____ set from ____ feet to ____ feet
Slot Size ____ set from ____ feet to ____ feet
Was packer or seal used? ☐ Yes ☐ No
If so, what material ____ Depth ____ ft.
(stainless steel, bronze, etc.)
Type of well: Straight screen ☐ Gravel packed ☐
Depth grouted: From ____ To ____
Grouting Material: Cement ____ Other ____
If other explain: ____
Well head completion: Pitless unit Williams adapt
12" above grade ____ Other ____
If other, specify ____
Was pump installed: ☒ Yes ☐ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 65 feet below surface
If flowing: closed-in pressure ____ psi
GPM flow 12 through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify ____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:
80 ft. after 2 hrs. pumping 12 gpm
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
top soil	0	1 ft
Clay	1	26
Sand seep water	26	27
Clay + rock	27	80
Shale with water	80	100

(Use separate sheet if necessary)

10. DATE COMPLETED

August 2, 1996

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☐ No
If so, how ____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

G. N. Carlson — Carlson Drilling — 114
Driller's or Firm's Name — Certificate No.

3111 Hwy 20 S.E.
Address

Jamestown, N.D. — 8-6-96
Signed by — Date

Gerald N. Carlson

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY