STATE OF NORTH DAKOTA
**BOARD OF WATER WELL CONTRACTORS**
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

# WELL DRILLER'S REPORT

**State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.**

## 1. WELL OWNER
Name: David Wagner
Address: 795 71st St. N.E.
Towner, N.D. 58788

## 2. WELL LOCATION
Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: McHenry

____ 1/4 ____ 1/4 NE 1/4 Sec. 11 Twp. 157 N. Rg. 86 W.

## 3. PROPOSED USE
☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

## 4. METHOD DRILLED
☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

## 5. WATER QUALITY
Was a water sample collected for:
Chemical Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☐ Yes ☒ No
If so, to what laboratory was it sent? _____

## 6. WELL CONSTRUCTION
Diameter of hole 8 3/4 inches. Depth 33 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

| Pipe Weight: | Diameter: | From: | To: |
|---|---|---|---|
| 200 lb/ft | 5 inches | 0 feet | 33 feet |
| ____ lb/ft | ____ inches | ____ feet | ____ feet |
| ____ lb/ft | ____ inches | ____ feet | ____ feet |

Was perforated pipe used? ☒ Yes ☐ No
Perforated pipe set from 23 ft. to 33 feet
Was casing left open end? ☐ Yes ☒ No
Was a well screen installed? ☐ Yes ☒ No
Material _____ Diameter _____ inches
Slot Size _____ set from _____ feet to _____ feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☒ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☒
Depth grouted: From 10 To 20
Grouting Material: Cement _____ Other Enviroplug
If other, explain: _____
Well head completion: Pitless unit NO
12" above grade Yes Other _____
If other, specify _____
Was pump installed? ☐ Yes ☒ No
Was well disinfected upon completion? ☒ Yes ☐ No

## 7. WATER LEVEL
Static water level 5 feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

## 8. WELL TEST DATA
☐ Pump ☐ Bailer ☒ Other Air
Pumping level below land surface:
20 ft. after 1 hrs. pumping 12 gpm
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm

## 9. WELL LOG

| Formation | Depth (ft.) From | Depth (ft.) To |
|---|---|---|
| Surface | 0 | 1 |
| Sand | 1 | 33 |

(Use separate sheet if necessary)

## 10. DATE COMPLETED
10-22-03

## 11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☒ No
If so, how _____

## 12. REMARKS:

## 13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Hamer & Son Drilling & Excavating
7521 Cty. Rd. 15 W
Minot, ND 58703
Driller's or Firm's Name

#102
Certificate No.

Address

Signed by

11-15-03
Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY