

136-104-33

State of North Dakota
BOARD OF WATER WELL CONTRACTORS
900 E. Boulevard, Bismarck, North Dakota 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER

Name : Gene Davis
Address : Rural Route
City : Rhame
State : ND Zip Code: 58651
Phone : 279-5769

WATER LEVEL

Static water level: ft. below L.S.
If flowing; closed-in pressure: 2 psi
GPM flow: 0.5 through: 1 inch pipe
Controlled by: none


WELL TEST DATA

	Pump,	Bailer,	Other
ft. after:	hrs pumping		gpm
ft. after:	hrs pumping		gpm
ft. after:	hrs pumping		gpm

WELL LOCATION

Sketch map location must agree with written locations.

NORTH



1 Mile

County : Slope Section: 33
: SE 1/4 of, : NE 1/4 of, : SW 1/4
Township : 136 W Range : 104 W

PROPOSED USE

: Irrigation
: Domestic
: Municipal
: Geothermal
: X Stock
: Industrial
: Test hole

METHOD DRILLED

: Bored	: Jetted
: Cable	: Reverse Rotary
: X Forward Rotary,	: Other
if other, specify	

WATER QUALITY

Was a water sample collected for chemical analysis? : No
if so, to what laboratory was it sent
Address :

WELL LOG

From	To	Formation
0	1	top soil
1	91	sandy clay to sand
91	93	sand
93	119	clay
119	124	sand
124	136	clay
136	142	sand
142	162	clay
162	165	coal
165	188	sandy clay
188	210	sand
210	233	clay
233	245	sand
245	292	clay
292	302	coal
302	310	clay
310	307	coal
307	334	clay
334	337	coal
337	397	clay
397	384	coal
384	462	clay
462	538	sandy
538	542	coal
542	586	clay to sandy clay
586	613	sand
613	615	coal
615	704	clay
704	707	sand
707	736	clay to sandy clay

Continued on next page.

