STATE OF NORTH DAKOTA

# BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

# WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

**1. WELL OWNER**

Name Kermont Hollekim

Address Box 93 Palermo, ND

**2. WELL LOCATION**

Sketch map location must agree with written location.

NORTH



1 Mile

County Mountrail

NW ¼ NW ¼ SW ¼ Sec. 14 Twp. 156 N. Rg. 90 W.

**3. PROPOSED USE**

☒ Domestic ☐ Irrigation ☐ Industrial

☒ Stock ☐ Municipal ☐ Test Hole

**4. METHOD DRILLED**

☐ Cable ☐ Reverse Rotary ☐ Bored

☒ Forward Rotary ☐ Jetted ☐ Other

If other, specify

**5. WATER QUALITY**

Was a water sample collected for chemical analysis?

☐ Yes ☒ No

If so, to what laboratory was it sent

**6. WELL CONSTRUCTION**

Diameter of hole 8 3/4 inches. Depth 148 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete

☐ Threaded ☐ Welded ☐ Other

If other, specify

| Pipe Weight: | Diameter: | From: | To: |
|---|---|---|---|
| 3 lb/ft. | 5 inches | 0 feet | 148 feet |
| lb/ft. | inches | feet | feet |
| lb/ft. | inches | feet | feet |
| lb/ft. | inches | feet | feet |

Was perforated pipe used? ☒ Yes ☐ No

Length of pipe perforated 28 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screened installed? ☐ Yes ☒ No

Material _____ Diameter _____ inches
(stainless steel, bronze, etc.)

Slot size .032 set from 120 feet to 148 feet

Slot size _____ set from _____ feet to _____ feet

Slot size _____ set from _____ feet to _____ feet

Slot size _____ set from _____ feet to _____ feet

Was a packer or seal used? ☐ Yes ☒ No

If so, what material

Type of well: Straight screen ☐ Gravel packed ☒

Was the well grouted? Yes ☒ No ☐

To what depth? 113 feet

Material used in grouting drill filings

Well head completion: Pitless adapter

12" above grade X Other

If other, specify

Was well disinfected upon completion? ☐ Yes ☒ No

**7. WATER LEVEL**

Static water level 60 feet below land surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

**8. WELL TEST DATA**

☐ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

70 ft. after ½ hrs. pumping 20 gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

**9. WELL LOG**

| Formation | Depth (ft.) From | Depth (ft.) To |
|---|---|---|
| top soil | 0 | 1 |
| yellow clay | 1 | 22 |
| blue & yellow clay | 22 | 39 |
| fine blue sand | 39 | 70 |
| Blue clay | 70 | 120 |
| fine blue sand | 120 | 148 |

(Use separate sheet if necessary.)

**10. DATE COMPLETED** Dec. 2, 1982

**11. WAS WELL PLUGGED OR ABANDONED?**

☐ Yes ☒ No

If so, how

**12. REMARKS:** Top ten feet of well to be grouted w/cement by owner.

**13. DRILLER'S CERTIFICATION**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Crowder-Dennis Drlg. #61

Driller's or Firm's Name Certificate No.

RR2 Box 6A Stanley, ND 58784

Address

James C. Dennis 12/4/82

Signed by Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY