STATE OF NORTH DAKOTA

# BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

# WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

**1. WELL OWNER**

Name Darol Belich

Address Tioga n. Dak.

**2. WELL LOCATION**

Sketch map location must agree with written location.

NORTH

1 Mile

Sec. [1 Mile]

County mountrail

¼NW ¼NE ¼ Sec. 6 Twp. 156 N. Rg. 93 W.

**3. PROPOSED USE**

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

**4. METHOD DRILLED**

☒ Cable ☐ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify

**5. WATER QUALITY**

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☐ Yes ☒ No

If so, to what laboratory was it sent

**6. WELL CONSTRUCTION**

Diameter of hole 9 7/8 inches. Depth 110 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify

| Pipe Weight: | Diameter: | From: | To: |
|---|---|---|---|
| 200 lb/ft. | 4 inches | 0 feet | 110 feet |
| lb/ft. | inches | feet | feet |
| lb/ft. | inches | feet | feet |

Was perforated pipe used? ☐ Yes ☐ No

Perforated pipe set from 100 ft to 110 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screened installed? ☒ Yes ☐ No

Material Plastic Diameter 4 inches
(stainless steel, bronze, etc.)

Slot size 30 set from 106 feet to 110 feet

Slot size set from feet to feet

Was a packer or seal used? ☒ Yes ☐ No

If so, what material 90 Depth 10 Ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 0 To 20

Grouting Material: Cement ✓ Other

If other explain:

Well head completion: Pitless unit NO

12" above grade 36 Other

If other, specify

Was pump installed: ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

**7. WATER LEVEL**

Static water level feet below land surface

If flowing: closed-in pressure psi

GPM flow through inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

**8. WELL TEST DATA**

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

80 ft. after 10 hrs. pumping 3 gpm

ft. after hrs. pumping gpm

ft. after hrs. pumping gpm

**9. WELL LOG**

| Formation | Depth (ft.) From | Depth (ft.) To |
|---|---|---|
| top | 0 | 3 |
| Br. Til | 3 | 9 |
| Gravel | 9 | 11 |
| Br. Til | 11 | 18 |
| Gray Til | 18 | 52 |
| Br. sandy clay + gravel | 52 | 80 |
| Gray sandy clay | 80 | 87 |
| Gray sand. muddy. | 87 | 91 |
| Br. sand trace W | 91 | 94 |
| Br. sand muddy | 94 | 104 |
| Hard pan | 104 | 106 |
| Gray sand + water | 106 | 110 |

(Use separate sheet if necessary.)

**10. DATE COMPLETED** 8-21-91

**11. WAS WELL PLUGGED OR ABANDONED?**

☐ Yes ☒ No

If so, how

**12. REMARKS:**

[redacted]

**13. DRILLER'S CERTIFICATION**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Dennis Tandeski Drill 24

Driller's or Firm's Name Certificate No.

BR-3-Box 5. Tioga n. Dak.

Address

Dennis Tandeski. 8-22-91

Signed by Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY