STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Dickinson High School

Address: North Empire Rd

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: Stark

NW 1/4 SE 1/4 SE 1/4 Sec. 4 Twp. 140 N. Rg 96 W.

3. PROPOSED USE

☑ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☑ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:

Chemcial Analysis? ☑ Yes ☐ No

Bacteriological Analysis? ☑ Yes ☐ No

If so, to what laboratory was it sent? State Health Dept

6. WELL CONSTRUCTION

Diameter of hole 9 inches. Depth 0-80 feet.

Casing: ☐ Steel ☑ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	5 inches	0 feet	40 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☑ Yes ☐ No

Perforated pipe set from 40 ft to 80 feet

Was casing left open end? ☐ Yes ☑ No

Was a well screened installed? ☐ Yes ☑ No

Material _____ Diameter _____ inches

Slot Size .025 set from _____ feet to _____ feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☑

Depth grouted: From 0 To 20 Ft

Grouting Material: Cement _____ Other Bentonite

If other explain: _____

Well head completion: Pitless unit No

12" above grade YES Other _____

If other, specify _____

Was pump installed: ☐ Yes ☑ No

Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL

Static water level 18 feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☐ Pump ☑ Bailer ☐ Other

Pumping level below land surface:

38 ft. after 1 hrs. pumping 40 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top Soil	0	2
Brn Sand	2	10
Sand Rock	10	12
Sand Rock	12	23
Brn Sand	23	30
Brn Sand	30	37
Blu Sand	37	40
Blu Sand	40	50
Clay Rock + Blu Sand	50	56
Blu Sand + clay Rock	56	60
Clay Rock	60	63
Blu Sand	63	70
Blu Sand	70	80
Blu Clay	80	82

(Use separate sheet if necessary)

10. DATE COMPLETED 10-26-98

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☑ No

If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Anton Drilling — Driller's or Firm's Name

108 — Certificate No

1568 13ST WEST DICKINSON, N.D. — Address

Jack Anton — Signed by

10-28-98 — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY