STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Jack Redman

Address Tioga N. Dak

2. WELL LOCATION

Sketch map location must agree with written location.



County Williams

SE ¼ SE ¼ SE ¼ Sec. 10 Twp. 158 N. Rg. 95 W.

3. PROPOSED USE

☐ Geothermal ☐ Monitoring
☒ Domestic ☐ Irrigation ☐ Industrial
☐ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☒ Cable ☐ Reverse Rotary ☐ Bored
☐ Forward Rotary ☐ Jetted ☐ Auger

If other, specify

5. WATER QUALITY

Was a water sample collected for chemical analysis?

☐ Yes ☒ No

If so, to what laboratory was it sent

6. WELL CONSTRUCTION

Diameter of hole 8 inches. Depth 102 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
200 lb/ft.	4 inches	0 feet	102 feet
lb/ft.	inches	feet	feet
lb/ft.	inches	feet	feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 10 ft to feet

Was casing left open end? ☒ Yes ☐ No

Was a well screened installed? ☒ Yes ☐ No

Material plastic Diameter 4 inches
(stainless steel, bronze, etc.)

Slot size 32 set from 88 feet to 102 feet

Slot size set from feet to feet

Was a packer or seal used? ☒ Yes ☐ No

If so, what material Cement Depth 9-20 Ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 9. To 20.

Grouting Material: Cement ✓ Other

If other explain:

Well head completion: Pitless unit

12" above grade Other

If other, specify

Was pump installed: ☐ Yes ☒ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 80 feet below land surface

If flowing: closed-in pressure psi

GPM flow through inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

100 ft. after 48 hrs. pumping 2. gpm

ft. after hrs. pumping gpm

ft. after hrs. pumping gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Gray Clay	0	20
Brown Sandy clay	20	47
Brown Sand. muddy	47	49
Brown clay	49	63
Brown Sand.	63	64
Brown clay & Gravel	64	96
Brown Sand & Gravel	96	98
Brown Sand.	98	101
Brown Sandstone	101	102

(Use separate sheet if necessary.)

10. DATE COMPLETED 9-6-92

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Tandeski Nr. Well Drilling - 21
Driller's or Firm's Name Certificate No.

RR. 3 - Box 5 - Tioga N. Dak.
Address

Dennis Tandeski 9-20-92
Signed by Date

WHITE—DRILLER'S COPY YELLOW—BOARD'S COPY PINK—CUSTOMER'S COPY