STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER
Name: Paul Thomas
Address: #34 Heritage Drive
Velva, N.D. 58790

2. WELL LOCATION
Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: McHenry

_____ 1/4 N 1/4 NE 1/4 Sec. 28 Twp. 154 N. Rg 78 W.

3. PROPOSED USE
☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED
☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY
Was a water sample collected for:
Chemical Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☐ Yes ☒ No
If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION
Diameter of hole 8 3/4 inches. Depth 62 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	5 inches	0 feet	62 feet
_____ lb/ft	_____ inches	_____ feet	_____ feet
_____ lb/ft	_____ inches	_____ feet	_____ feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 42 ft. to 62 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screen installed? ☐ Yes ☒ No

Material _____ Diameter _____ inches

Slot Size _____ set from _____ feet to _____ feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 35 To 3

Grouting Material: Cement _____ Other Enviroplug

If other, explain: _____

Well head completion: Pitless unit No

12" above grade Yes Other _____

If other, specify _____

Was pump installed? ☐ Yes ☒ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL
Static water level 40 feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA
☐ Pump ☐ Bailer ☒ Other A.R

Pumping level below land surface:

50 ft. after 2 1/2 hrs. pumping 6 gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Surface	0	1
Sand & Gravel	1	53
Clay	53	55
Sand & Gravel	55	62

(Use separate sheet if necessary)

10. DATE COMPLETED 5-28-04

11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☒ No

If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Mariner & Son Drilling & Excavating #102
7521 Cty. Rd. 15 W
Minot, ND 58703

Driller's or Firm's Name — Certificate No.

Address

[signature] 5-30-04

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY