STATE OF NORTH DAKOTA
**BOARD OF WATER WELL CONTRACTORS**
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

# WELL DRILLER'S REPORT

**State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.**

## 1. WELL OWNER

Name RAY DARNEAU
Address RR2 Box 7 Williston ND

## 2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile)_____

County WILLIAMS

SW 1/4 SW 1/4 SW 1/4 Sec. 13 Twp. 157 N. Rg. 100 W.

## 3. PROPOSED USE

☐ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

## 4. METHOD DRILLED

☐ Cable ☑ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

## 5. WATER QUALITY

Was a water sample collected for:
Chemical Analysis? ☐ Yes ☑ No
Bacteriological Analysis? ☐ Yes ☑ No
If so, to what laboratory was it sent? _____

## 6. WELL CONSTRUCTION

Diameter of hole 8 3/4 inches. Depth 105 feet.

Casing: ☐ Steel ☑ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☑ Other

If other, specify GLUED

| Pipe Weight: | Diameter: | From: | To: |
|---|---|---|---|
| 200 lb/ft | 5 inches | 2 feet | 105 feet |
| ____ lb/ft | ____ inches | ____ feet | ____ feet |
| ____ lb/ft | ____ inches | ____ feet | ____ feet |

Was perforated pipe used? ☐ Yes ☐ No
Perforated pipe set from _____ ft. to _____ feet
Was casing left open end? ☐ Yes ☑ No
Was a well screen installed? ☑ Yes ☐ No
Material PLASTIC Diameter 5" inches
Slot Size 0.20 set from 85 feet to 105 feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☑ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☑ SAND
Depth grouted: From 10 To 30
Grouting Material: Cement _____ Other _____
If other, explain: Bentonite pellet Mud
Well head completion: Pitless unit Yes
12" above grade Yes Other _____
If other, specify _____
Was pump installed? ☑ Yes ☐ No
Was well disinfected upon completion? ☑ Yes ☐ No

## 7. WATER LEVEL

Static water level 88 feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

## 8. WELL TEST DATA

☐ Pump ☐ Bailer ☑ Other air lift
Pumping level below land surface:
100 ft. after 7 hrs. pumping 8 gpm
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm

## 9. WELL LOG

| Formation | Depth (ft.) From | Depth (ft.) To |
|---|---|---|
| Cl. gRV & Rock | 0 | 30 |
| GRV | 30 | 32 |
| S Cl & gRV mix | 32 | 40 |
| S & gRV BR Lots of S | 40 | 60 |
| S + Big gRV | 60 | 65 |
| Big gRV | 65 | 75 |
| BR Cl & S | 75 | 80 |
| Cl | 80 | 81 |
| Big gRV | 81 | 103 |
| S + gRV | 103 | 105 |

(Use separate sheet if necessary)

## 10. DATE COMPLETED 8/28/05

## 11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☑ No
If so, how _____

## 12. REMARKS:

HARD well to DRILL
USE Lots of DRILL
Mud Static Kept DROPING

## 13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

FUNKBEINER DRILLING 176
Driller's or Firm's Name Certificate No.
Box 217 Williston ND
Address
Eldon Funkbeiner 8/29/05
Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY