STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Gary Wyside

Address: PR Bottineau

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: Bottineau

SE 1/4 NE 1/4 NE 1/4 Sec. 34 Twp. 164 N. Rg 75 W.

3. PROPOSED USE

☐ Geothermal ☐ Monitoring
☒ Domestic ☐ Irrigation ☐ Industrial
☐ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored
☒ Forward Rotary ☐ Jetted ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☒ Yes ☐ No

If so, to what laboratory was it sent? 1st Dist Health

6. WELL CONSTRUCTION

Diameter of hole 4 inches. Depth 102 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 psi lb/ft	4 inches	0 feet	102 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 82 ft. to 102 feet

Was casing left open end? ☒ Yes ☐ No

Was a well screen installed? ☒ Yes ☐ No

Material plastic Diameter 4 inches

Slot Size .020 set from 82 feet to 102 feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 8 To 25

Grouting Material: Cement NO Other X

If other, explain: Bentonite Grout.

Well head completion: Pitless unit monitor

12" above grade yes Other _____

If other, specify _____

Was pump installed? ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 32 feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

67 ft. after 24 hrs. pumping 6 gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top Soil	0	1
Yellow clay & Rock	1	25
Blue-Gray Clay	25	65
Rock	65	67
Gray Clay & Rock	67	80
med mixed sand	80	101
Clay.	101	102

(Use separate sheet if necessary)

10. DATE COMPLETED

Nov 15-05

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how _____

12. REMARKS:

For a Year Around Home at Lake.

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Leslie D Nelson — 125

Driller's or Firm's Name — Certificate No.

1561 1030 St NE Bottineau

Address

Leslie D Nelson — 11/30/05

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY