STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Jerany Helde

Address: 1813 31st St W.
Williston ND 58801

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: Williams

_____ 1/4 _____ 1/4 SE 1/4 Sec. 26 Twp. 155 N. Rg 99 W.

3. PROPOSED USE

☐ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

By Owner

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☐ No

Bacteriological Analysis? ☐ Yes ☐ No

If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION

Diameter of hole 8 3/4 inches. Depth 123 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	5 inches	2 feet	103 feet
_____ lb/ft	_____ inches	_____ feet	_____ feet
_____ lb/ft	_____ inches	_____ feet	_____ feet

Was perforated pipe used? ☐ Yes ☒ No

Perforated pipe set from _____ ft. to _____ feet

Was casing left open end? ☐ Yes ☒ No

Was a well screen installed? ☒ Yes ☐ No

Material Plastic Diameter 5 inches

Slot Size .020 set from 103 feet to 123 feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 47 To 15

Grouting Material: Cement _____ Other Kwik plug

If other, explain: _____

Well head completion: Pitless unit No

12" above grade Yes Other _____

If other, specify _____

Was pump installed? ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 82 feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

119 ft. after 3 hrs. pumping 3 1/2 gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top Soil	0	1
Brown Pebbly Clay	1	16
Sand (Course)	16	27
Blue Clay	27	69
Coal	69	79
Blue Clay	79	100
Coal w/streaks of Blue Clay	100	120
Blue Clay	120	123

(Use separate sheet if necessary)

10. DATE COMPLETED June 30 07

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Dan's Drilling & Well Service 124

Driller's or Firm's Name Certificate No.

5332 134th Ave NW
Williston ND 58801

Address

Duane Fritz June 30 07

Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY