STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER
Name: Paul Ogden
Address: Box 1042
Stanley ND 58784

2. WELL LOCATION
Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: Mountrail

_____ 1/4 _____ 1/4 NW 1/4 Sec. 11 Twp. 155 N. Rg 92 W.

3. PROPOSED USE
☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED
☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY
By Owner

Was a water sample collected for:
Chemical Analysis? ☐ Yes ☐ No
Bacteriological Analysis? ☐ Yes ☐ No
If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION
Diameter of hole 8 3/4" inches. Depth 108 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	5 inches	2 feet	98 feet
_____ lb/ft	_____ inches	_____ feet	_____ feet
_____ lb/ft	_____ inches	_____ feet	_____ feet

Was perforated pipe used? ☐ Yes ☒ No
Perforated pipe set from _____ ft. to _____ feet
Was casing left open end? ☐ Yes ☒ No
Was a well screen installed? ☒ Yes ☐ No
Material Plastic Diameter 5 inches
Slot Size .020 set from 98 feet to 108 feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☒ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☒
Depth grouted: From 35 To 15
Grouting Material: Cement _____ Other Kwikplug
If other, explain: _____
Well head completion: Pitless unit No
12" above grade Yes Other _____
If other, specify _____
Was pump installed? ☒ Yes ☐ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL
Static water level 39 feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through _____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

8. WELL TEST DATA
☒ Pump ☐ Bailer ☐ Other
Pumping level below land surface:
105 ft. after 4 hrs. pumping 7 gpm
_____ ft. after _____ hrs. pumping _____ gpm
_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top Soil	0	1
Brown Clay	1	10
Sandy Gravel	10	20
Brown Clay	20	35
Sandy Blue Clay	35	51
Gravel	51	55
Blue Clay w/streaks of gravel	55	78
Sand	78	105
Blue Clay	105	108

(Use separate sheet if necessary)

10. DATE COMPLETED 8-19-07

11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☒ No
If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Dan's Drilling & Well Service 124
Driller's or Firm's Name — Certificate No.
5332 134th Ave NW Williston ND 58801
Address
Dwane Kurtz 8-19-07
Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY