STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Eric Skretteberg
Address: 5895 54th Ave SW
Carson, ND 58529

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: Grant

SE 1/4 SE 1/4 SW 1/4 Sec. 30 Twp. 136 N. Rg 86 W.

3. PROPOSED USE

☒ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:
Chemical Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☒ Yes ☐ No
If so, to what laboratory was it sent? MVTL

6. WELL CONSTRUCTION

Diameter of hole 7 7/8 inches. Depth 395 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	4 inches	0 feet	395 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☒ Yes ☐ No
Perforated pipe set from 335 ft. to 375 feet
Was casing left open end? ☐ Yes PVC CAPPED ☒ No
Was a well screen installed? ☐ Yes ☒ No
Material _____ Diameter _____ inches
Slot Size _____ set from _____ feet to _____ feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☒ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☒ SAND
Depth grouted: From 8' to 50' To 240 to 300
Grouting Material: Cement X Other Bentonite
If other, explain: Bentonite Pellets
Well head completion: Pitless unit X
12" above grade _____ Other _____
If other, specify _____
Was pump installed? ☒ Yes ☐ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level surface feet below surface
If flowing: closed-in pressure 0 psi
GPM flow 6 through 4 inch pipe
Controlled by: ☐ Valve ☐ Reducers ☒ Other
If other, specify Pitless unit

8. WELL TEST DATA

☒ Pump ☐ Bailer ☒ Other Air

Pumping level below land surface:

ft.	after hrs.	pumping	gpm
10' 2"	2	15	
22	1	50+	

9. WELL LOG

Formation		Depth (ft.) From	To
Surface Soil 0-2	CLAY	240	252
CLAY 2-10	Gray SANDY CLAY	252	260
Gravel 11-12	Fine SAND	260	278
CLAY 12-14	COAL	278	282
Gravel 14-17	COAL SHACK	282	284
CLAY 17-106	CLAY	284	308
Fine SAND w/ seashells 106-112	Limestone	313	315
CLAY 112-126	Green SAND	315	332
Green SANDY CLAY/coal 126-135	Limestone	332	334
CLAY 135-150	SAND	334	360
Gray SANDY CLAY 150-155	SAND w/coal	360	375
CLAY 155-182	CLAY	375	395
Limestone 182-183			
Gray SANDY CLAY 183-196			
CLAY 196-200			
Gray SANDY CLAY 200-210			
CLAY 210-216			
Limestone 216-217			
CLAY 217-220			
DARK CLAY w/coal 220-235			
Fine Green SAND 235-240			

(Use separate sheet if necessary)

10. DATE COMPLETED 7-23-2007

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Wetch & Sons Drilling — 103
Driller's or Firm's Name — Certificate No.
Box 472, Mandan, N.D. — 58554
Address
[signature] — 8-1-2007
Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY