STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Allen Schmidt
Address: 919 1st Av W
New England ND

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) ____

County ____

SE 1/4 SE 1/4 SE 1/4 Sec. 4 Twp. 136 N. Rg 97 W.

3. PROPOSED USE

☐ Geothermal ☐ Monitoring
☑ Domestic ☐ Irrigation ☐ Industrial
☐ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored
☑ Forward Rotary ☐ Jetted ☐ Auger

If other, specify ____

5. WATER QUALITY

Was a water sample collected for:
Chemical Analysis? ☐ Yes ☑ No
Bacteriological Analysis? ☐ Yes ☑ No
If so, to what laboratory was it sent? ____

6. WELL CONSTRUCTION

Diameter of hole 8" inches. Depth 110 feet.

Casing: ☐ Steel ☑ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify ____

Pipe Weight:	Diameter:	From:	To:
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☑ Yes ☐ No
Perforated pipe set from 95 ft. to 110 feet
Was casing left open end? ☑ Yes ☐ No
Was a well screen installed? ☐ Yes ☑ No
Material ____ Diameter ____ inches
Slot Size ____ set from ____ feet to ____ feet
Slot Size ____ set from ____ feet to ____ feet
Was packer or seal used? ☐ Yes ☑ No
If so, what material ____ Depth ____ ft.
Type of well: Straight screen ☐ Gravel packed ☑
Depth grouted: From 0 To 30'
Grouting Material: Cement Bentonite Other ____
If other, explain: ____
Well head completion: Pitless unit ____
12" above grade ✓ Other ____
If other, specify ____
Was pump installed? ☐ Yes ☑ No
Was well disinfected upon completion? ☐ Yes ☐ No

7. WATER LEVEL

Static water level 75 feet below surface
If flowing: closed-in pressure — psi
GPM flow — through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify ____

8. WELL TEST DATA

☐ Pump ☑ Bailer ☐ Other
Pumping level below land surface:
80 ft. after 1 hrs. pumping 10 gpm
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Yellow Sand	1	10
Sandy Clay	10	25
Coarse Sand	25	66
Blue Sand	66	80
Blue Sand/layer of fine coal	80	110

(Use separate sheet if necessary)

10. DATE COMPLETED Sept 1 - 08

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☑ No
If so, how ____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Wallace Beardsley 55
Driller's or Firm's Name Certificate No.
921 4th Ave E
Address
Dickinson ND 58601
Signed by Wallace Beardsley Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY