STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Clyde Reister

Address

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile)

County Stutsman

NE 1/4 SE 1/4 SE 1/4 Sec. 22 Twp. 138 N. Rg 69 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☐ No

Bacteriological Analysis? ☐ Yes ☐ No

If so, to what laboratory was it sent? given to owner

6. WELL CONSTRUCTION

Diameter of hole 8 inches. Depth 138 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☐ Yes ☒ No

Perforated pipe set from ft. to feet

Was casing left open end? ☐ Yes ☒ No

Was a well screen installed? ☒ Yes ☐ No

Material Plastic Diameter 4 inches

Slot Size .032 set from 122 feet to 138 feet

Slot Size set from feet to feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material Depth ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 17 To 40

Grouting Material: Cement Other X

If other, explain: Bentonite Chips

Well head completion: Pitless unit

12" above grade X Other

If other, specify

Was pump installed? ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 30 feet below surface

If flowing: closed-in pressure psi

GPM flow through inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other

Pumping level below land surface:

ft. after hrs. pumping gpm

ft. after hrs. pumping gpm

ft. after hrs. pumping gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
~~Top Soil~~		
Top Soil	0	1
Yellow Till	1	17
Gray Till	17	55
Medium gravel	55	70
Gray Till	70	122
Medium to fine Sand	122	138
Shale	138	144

(Use separate sheet if necessary)

10. DATE COMPLETED 10-22-08

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how

12. REMARKS:

Land owner will take care of Water sample C.R.

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Schimelpenig Well Drilling Inc. 155

Driller's or Firm's Name Certificate No.

535 N 2nd St Carrington

Address

Signed by 11/12/08 Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY