STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Gerald Roller
Address: Harvey ND

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County: Pierce

SE 1/4 SE 1/4 SW 1/4 Sec. 29 Twp. 151 N.Rg 73 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:
Chemical Analysis? ☐ Yes ☐ No
Bacteriological Analysis? ☒ Yes ☐ No
If so, to what laboratory was it sent? given to owner

6. WELL CONSTRUCTION

Diameter of hole 8 inches. Depth 70 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	5 inches	0 feet	57 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No
Perforated pipe set from _____ ft. to _____ feet
Was casing left open end? ☐ Yes ☒ No
Was a well screen installed? ☒ Yes ☐ No
Material Plastic Diameter 4 inches
Slot Size .03 set from 57 feet to 65 feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☒ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☒
Depth grouted: From 10 To 30
Grouting Material: Cement X Other X
If other, explain: Bentonite Chips
Well head completion: Pitless unit _____
12" above grade X Other _____
If other, specify _____
Was pump installed? ☐ Yes ☒ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 57 feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:
57 ft. after 2 hrs. pumping 10 gpm
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
TopSoil	0	1
Yellow till	1	27
gray till & Lime Stone	27	47
Medium Sand & Gravel	47	65
Rocks	65	70

(Use separate sheet if necessary)

10. DATE COMPLETED 10/30/08

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No
If so, how _____

12. REMARKS:

Landowner will take Care of Water Sample
OK

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Schimelfenig Well Drilling 139
Driller's or Firm's Name — Certificate No.

535 N 2nd St Carrington
Address

Ed Schimelfenig 10-30-08
Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY