STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Don Gienger

Address Streeter

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile) _____

County Stutsman

NW 1/4 NW 1/4 NW 1/4 Sec. 31 Twp. 136 N. Rg 69 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☐ No

Bacteriological Analysis? ☒ Yes ☐ No

If so, to what laboratory was it sent? given to owner

6. WELL CONSTRUCTION

Diameter of hole 8 inches. Depth 150 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
250 lb/ft	4 1/2 inches	0 feet	140 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No

Perforated pipe set from _____ ft. to _____ feet

Was casing left open end? ☐ Yes ☒ No

Was a well screen installed? ☒ Yes ☐ No

Material Plastic Diameter 4 inches

Slot Size .032 set from 140 feet to 150 feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 10 To 40

Grouting Material: Cement X Other X

If other, explain: Bentonite Chips

Well head completion: Pitless unit _____

12" above grade X Other _____

If other, specify _____

Was pump installed? ☐ Yes ☒ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 35 feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other

Pumping level below land surface:

150 ft. after 1 hrs. pumping 30 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
TopSoil	0	1
yellow till	1	27
gray till	27	130
medium to course gravel	130	151
Shale	151	157

(Use separate sheet if necessary)

10. DATE COMPLETED 10/14/08

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how _____

12. REMARKS:

Landowner will Take care of water Sample

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Schimetheny Well Drilling 155

Driller's or Firm's Name Certificate No.

535 N 2nd St Carrington

Address

[signature] 10/15/08

Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY