STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD • BISMARCK, NORTH DAKOTA 58501

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Wachter Home & Bottling

Address

2. WELL LOCATION

Sketch map location must agree with written location.

NORTH

1 MILE

Sec. (1 mile)

County Burleigh

___ 1/4 NE 1/4 NW 1/4 Sec. 10 Twp. 138 N. Rg 80 W.

3. PROPOSED USE

☑ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☑ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify

5. WATER QUALITY

Sent in by owner

Was a water sample collected for:

Chemcial Analysis? ☐ Yes ☐ No

Bacteriological Analysis? ☐ Yes ☐ No

If so, to what laboratory was it sent?

6. WELL CONSTRUCTION

Diameter of hole 8 inches. Depth 55 feet.

Casing: ☐ Steel ☑ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
2 lb/ft	4 inches	0 feet	35 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☐ Yes ☑ No

Perforated pipe set from ___ ft to ___ feet

Was casing left open end? ☐ Yes ☑ No

Was a well screened installed? ☑ Yes ☐ No

Material Plastic Diameter 4 inches

Slot Size 30 set from 35 feet to 55 feet

Slot Size ___ set from ___ feet to ___ feet

Was packer or seal used? ☐ Yes ☑ No

If so, what material ___ Depth ___ ft.

(stainless steel, bronze, etc.)

Type of well: Straight screen ☐ Gravel packed ☑

Depth grouted: From 0 To 35

Grouting Material: Cement ✓ Other Bentonite

If other explain:

Well head completion: Pitless unit ✓

12" above grade ___ Other ___

If other, specify

Was pump installed: ☑ Yes ☐ No

Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL

Static water level ___ feet below surface

If flowing: closed-in pressure ___ psi

GPM flow ___ through ___ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☑ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

30 ft. after ½ hrs. pumping 20 gpm

___ ft. after ___ hrs. pumping ___ gpm

___ ft. after ___ hrs. pumping ___ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Sandy Silt	0	15
Sand	15	35
Coarse Sand	35	55

(Use separate sheet if necessary)

10. DATE COMPLETED 11-4-96

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☑ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Zahner Well Drilling 26

Driller's or Firm's Name Certificate No

7252 Willow Rd Mdn N. Dak

Address

Tom Zahner 10/21/96

Signed by Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY