STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE. DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Illa McKay

Address: Tokio, N.D.

2. WELL LOCATION

Sketch map location must agree with written location.

GPS

EL

NORTH

1 MILE

X

Sec. (1 mile)

County: Benson

NE 1/4 SW 1/4 ____ 1/4 Sec. 26 Twp. 152 N.Rg. 64 W.

3. PROPOSED USE

☐ Geothermal ☐ Monitoring
☒ Domestic ☐ Irrigation ☐ Industrial
☐ Stock ☐ Municipal ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored
☒ Forward Rotary ☐ Jetted ☐ Auger

If other, specify

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☒ Yes ☐ No

Bacteriological Analysis? ☒ Yes ☐ No

If so, to what laboratory was it sent? Bismarck MVTL

6. WELL CONSTRUCTION

Diameter of hole 8½ inches. Depth 73 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
2.8 lb/ft	5 inches	+1 feet	61 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No

Perforated pipe set from ____ ft. to ____ feet

Was casing left open end? ☐ Yes ☒ No

Was a well screen installed? ☒ Yes ☐ No

Material Stainless Steel Diameter 4" inches

Slot Size 18 set from 61 feet to 66 feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material ____ Depth ____ ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 7 To 34

Grouting Material: Cement ____ Other X

If other, explain: Enviro plug

Well head completion: Pitless unit X Monitor

12" above grade X Other

If other, specify

Was pump installed? ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 21 feet below surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

36 ft.	after 3	hrs.	pumping 18	gpm
____ ft.	after ____	hrs.	pumping ____	gpm
____ ft.	after ____	hrs.	pumping ____	gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Black Dirt	0	2
tan Clay	2	6
yellow clay	6	17
yellow Clay & Brown gravel	17	38
Clean brown sand	38	44
gray sand and Shale sand	44	73

(Use separate sheet if necessary)

10. DATE COMPLETED 5-20-15

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Holbeck Water Well Serv. 301

Driller's or Firm's Name — License No

8353 Hwy 2 Devils Lake, ND 58301

Address

Leo Johnson 6-15-15

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY