STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE. DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Clayton Quam

Address: Tolna

2. WELL LOCATION

Sketch map location must agree with written location.

GPS _____

EL _____

NORTH

1 MILE

Sec. (1 mile) _____

County: Griggs

SE NW 1/4 1/4 1/4 Sec. 5 Twp. 148 N. Rg. 61 W.

3. PROPOSED USE

☐ Domestic ☒ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☒ No

Bacteriological Analysis? ☐ Yes ☒ No

If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION

Diameter of hole 8 inches. Depth 56 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
2.8 lb/ft	5 inches	+1 feet	56 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☒ Yes ☐ No

Perforated pipe set from 36 ft. to 56 feet

Was casing left open end? ☐ Yes ☒ No

Was a well screen installed? ☐ Yes ☐ No

Material _____ Diameter _____ inches

Slot Size _____ set from _____ feet to _____ feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material _____ Depth _____ ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 6 To 32

Grouting Material: Cement _____ Other X

If other, explain: Enviroplug

Well head completion: Pitless unit _____

12" above grade X Other _____

If other, specify _____

Was pump installed? ☐ Yes ☒ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 4' feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other air

Pumping level below land surface:

ft.	after hrs.	pumping	gpm
40	1½	30	

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Black dirt	0	9
Yellow Clay	9	17
yellow Clay & gravel	17	25
brown sand & gravel	25	38
gray sand & Shale some Clay stripe	38	60

(Use separate sheet if necessary)

10. DATE COMPLETED 5-8-15

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Holbeck Water Well 201

Driller's or Firm's Name — License No

8353 Hwy 2 Devils Lake, N.D.

Address

Les Johnson 5-30-15

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY