



WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well. STATE WATER COMMISSION

1. WELL OWNER

Name

Abby Ketterling


Address

2. WELL LOCATION

Sketch map location must agree with written location.

GPS

EL



County

Commons

SW 1/4 SW 1/4 SW 1/4 Sec. 18 Twp. 15 N. Rg. 75 W.

3. PROPOSED USE

☒ Domestic
☐ Stock

☐ Geothermal
☐ Irrigation
☐ Municipal
☐ Monitoring
☐ Industrial
☐ Test Hole

4. METHOD DRILLED

☒ Cable
☒ Forward Rotary

☐ Reverse Rotary
☐ Jetted
☐ Bored
☐ Auger

If other, specify

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis?

☐ Yes

☒ No

Bacteriological Analysis?

☐ Yes

☒ No

If so, to what laboratory was it sent?

6. WELL CONSTRUCTION

Diameter of hole 8 3/4 inches. Depth 91 feet.

Casing:

☐ Steel

☒ Plastic

☐ Concrete

☐ Threaded

☐ Welded

☐ Other

If other, specify

Pipe Weight:

Diameter:

From:

To:

SDR21 lb/ft 5 inches 10 feet 51 feet

lb/ft inches feet feet

lb/ft inches feet feet

Was perforated pipe used?

☐ Yes

☐ No

Perforated pipe set from ft. to feet

Was casing left open end?

☐ Yes

☐ No

Was a well screen installed?

☐ Yes

☐ No

Material PVC Diameter 5 inches

Slot Size 014 set from 51 feet to 91 feet

Slot Size set from feet to feet

Was packer or seal used?

☐ Yes

☐ No

If so, what material Depth ft.

Type of well: Straight screen ☐

Gravel packed ☒

Depth grouted: From 2 To 30

Grouting Material: Cement Other Bentonite

If other, explain:

Well head completion: Pitless unit 5x6 monitor

12" above grade Other

If other, specify

Was pump installed?

☒ Yes

☐ No

Was well disinfected upon completion?

☒ Yes

☐ No

7. WATER LEVEL

Static water level feet below surface

If flowing: closed-in pressure psi

GPM flow through inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify

8. WELL TEST DATA

☐ Pump

☐ Bailor

☒ Other

Pumping level below land surface:

From 70 ft. after 2 hrs. pumping 13 gpm

ft. after hrs. pumping gpm

ft. after hrs. pumping gpm

9. WELL LOG

Formation

Depth (ft.)

From

To

Y-1 clay	0	22
Brown sandy clay	22	42
Gray sand	42	52
Gray clay; sandstone	52	91
Gray clay	91	100

(Use separate sheet if necessary)

10. DATE COMPLETED 10-10-18

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes

☒ No

If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Quick Silver Well 21

Driller's or Firm's Name

License No

Driscoll ND

Address

Acorn Bore 10-29-18

Signed by

Date