#577
12"x42'x10' (120slot)

STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

RECEIVED
MAY 12 2020
STATE WATER COMMISSION

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER
Name: Wes Ewine
Address: 1618 N 26th St
Bismarck, ND 58501

2. WELL LOCATION
Sketch map location must agree with written location.

GPS _____
_____
_____
EL _____

NORTH
1 MILE
Sec. (1 mile) _____

County: McLean
SW 1/4 SW 1/4 NE 1/4 Sec. 27 Twp. 144 N. Rg. 80 W.

3. PROPOSED USE
☐ Domestic ☐ Stock ☒ Irrigation ☐ Municipal ☐ Geothermal ☐ Industrial ☐ Monitoring ☐ Test Hole

4. METHOD DRILLED
☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger
If other, specify _____

5. WATER QUALITY
Was a water sample collected for:
Chemical Analysis? ☐ Yes ☐ No
Bacteriological Analysis? ☐ Yes ☐ No
If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION
Diameter of hole 12 inches. Depth 42 feet.
Casing: ☒ Steel ☐ Plastic ☐ Concrete ☐ Threaded ☒ Welded ☐ Other
If other, specify _____

Pipe Weight:	Diameter:	From:	To:
____ lb/ft	12 inches	0 feet	32 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No
Perforated pipe set from _____ ft. to _____ feet
Was casing left open end? ☐ Yes ☒ No
Was a well screen installed? ☒ Yes ☐ No
Material: Stainless Steel Diameter 12 inches
Slot Size 120 set from 32 feet to 42 feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☐ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☒
Depth grouted: From 0 To 22
Grouting Material: Cement _____ Other Bentonite
If other, explain: _____
Well head completion: Pitless unit _____
12" above grade _____ Other _____
If other, specify _____
Was pump installed? ☐ Yes ☒ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL
Static water level 13 feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

8. WELL TEST DATA
☐ Pump ☐ Bailer ☒ Other Est. Blowing
Pumping level below land surface:
_____ ft. after _____ hrs. pumping 300 gpm
_____ ft. after _____ hrs. pumping _____ gpm
_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation		Depth (ft.) From	Depth (ft.) To
TS	Blk	0	1
Cly	Brn	1	9
Snd	Gry	9	30
Snd	Gry	30	42
Cly	Gry	42	50

(Use separate sheet if necessary)

10. DATE COMPLETED 5-6-2020

11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☒ No
If so, how _____

12. REMARKS:
Steve Brad Rick Frank

13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

STEVEN M. TRAUT WELLS, INC.
754 CROSS COUNTRY LANE S.W.
ALEXANDRIA, MN 56308
Driller's or Firm's Name
Address

85
Certificate No.

Signed by
5-6-20
Date

WHITE-BOARD'S COPY YELLOW-DRILLER'S COPY PINK-CUSTOMER'S COPY