STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

RECEIVED
AUG - 2 2021
ND DEPT. OF WATER RESOURCES

1. WELL OWNER
Name David Carpenter
Address 11200 249 St SE
Moffit

2. WELL LOCATION
Sketch map location must agree with written location.

GPS _____
_____
_____
EL _____

NORTH
1 MILE
Sec. (1 mile) _____

County _____
NE 1/4 SW 1/4 SW 1/4 Sec. 16 Twp. 137 N. Rg. 77 W.

3. PROPOSED USE
☐ Domestic ☐ Geothermal ☐ Monitoring
☑ Stock ☐ Irrigation ☐ Industrial
☐ Municipal ☐ Test Hole

4. METHOD DRILLED
☐ Cable ☐ Reverse Rotary ☐ Bored
☑ Forward Rotary ☐ Jetted ☐ Auger
If other, specify _____

5. WATER QUALITY
Was a water sample collected for:
Chemical Analysis? ☐ Yes ☑ No
Bacteriological Analysis? ☐ Yes ☑ No
If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION
Diameter of hole 8 3/4 inches. Depth 215 feet.
Casing: ☐ Steel ☑ Plastic ☐ Concrete
☐ Threaded ☐ Welded ☐ Other
If other, specify _____

Pipe Weight:	Diameter:	From:	To:
SDR 21 lb/ft	5 inches	0 feet	215 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☐ No
Perforated pipe set from _____ ft. to _____ feet
Was casing left open end? ☐ Yes ☑ No
Was a well screen installed? ☑ Yes ☐ No
Material PVC Diameter 5 inches
Slot Size 016 set from 195 feet to 215 feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☑ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☑
Depth grouted: From 0 To 30
Grouting Material: Cement _____ Other Bentonit
If other, explain: _____
Well head completion: Pitless unit _____
12" above grade _____ Other _____
If other, specify _____
Was pump installed? ☐ Yes ☑ No
Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL
Static water level 87' feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

8. WELL TEST DATA
☐ Pump ☐ Bailer ☐ Other
Pumping level below land surface:
170 ft. after 2 hrs. pumping 7½ gpm
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
brn sand	0	35
Gray clay	35	185
Sandy clay	185	195
blue sand	195	220
Gray clay	220	230

(Use separate sheet if necessary)

10. DATE COMPLETED 7-21-21

11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☑ No
If so, how _____

12. REMARKS:

13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Quicks Water Well 21
Driller's or Firm's Name Certificate No.

Driscoll
Address

Aaron Berg 7-30-21
Signed by Date

WHITE-BOARD'S COPY YELLOW-DRILLER'S COPY PINK-CUSTOMER'S COPY