




WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

JUN 10 2022

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Laverne Teske</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>Scranton ND</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>10 FT</u>			
		County <u>Slope</u>		GPS		If Flowing, Closed-In Pressure In PSI	
		<u>Bowman</u>					
1/4 <u>SW</u>		1/4 <u>SW</u>		1/4 <u>SE</u>		GPM Flow Through Inch Pipe	
Township <u>133</u>		Range <u>99</u>		Section <u>19</u>		Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____	
PROPOSED USE <u>13309911DCC</u>				WELL TEST DATA			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				☒ Pump ☐ Bailer ☐ Other			
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After <u>50</u> Hrs. Pumping <u>1</u> GPM <u>14</u>			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary				Feet After _____ Hrs. Pumping _____ GPM _____			
☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After _____ Hrs. Pumping _____ GPM _____			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
Bacteriological Analysis? ☐ Yes ☒ No				From To			
If So, To What Laboratory Was It Sent?				Top 0 1			
WELL CONSTRUCTION				Gray Sandy Clay 1 10			
Diameter Of Hole In Inches <u>7 7/8</u>		Depth In Feet <u>100</u>		Yellow loam 10 11			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other		☐ Threaded ☐ Welded ☐ If Other, Specify _____		Coal 11 15			
Pipe Weight <u>SD 21</u>	Diameter <u>4"</u>	From <u>0</u>	To <u>100</u>	Fine yellow sand 15 20			
lb/ft _____	inches _____	feet _____	feet _____	Gray clay 20 36			
lb/ft _____	inches _____	feet _____	feet _____	Very Fine Brown sand 36 40			
lb/ft _____	inches _____	feet _____	feet _____	Gray clay 40 45			
Was A Well Screen Installed? ☒ Yes ☐ No				Fine Gray sand 45 50			
Was Perforated Pipe Used? ☒ Yes ☐ No				Gray clay 50 65			
Screen Or Perforation Interval	From In Feet <u>70</u>	To In Feet <u>100</u>		Medium Gray sand 65 100			
Was Casing Left Open End? ☐ Yes ☒ No				Gray clay 100 119			
Material <u>PVC</u>	Diameter In Inches <u>4 1/2</u>			Coal 119 120			
Slot Size <u>16</u>	Set From In Feet <u>70</u>	To In Feet <u>100</u>		Use Separate Sheet If Necessary			
Slot Size _____	Set From In Feet _____	To In Feet _____		DATE COMPLETED <u>5-16-22</u>			
Was Packer Or Seal Used? ☐ Yes ☒ No				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
If So, What Material		Depth In Feet		If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed <u>SILICA</u>	Depth Grouted <u>65</u> From <u>69</u> To <u>65</u>			REMARKS			
Grouting Material		Cement <u>X</u> Other _____					
If Other, Explain: <u>BENT CAINS</u>							
Well Head Completion: Pitless Unit <u>YES</u>				DRILLER'S CERTIFICATION			
12" Above Grade <u>YES</u>		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>Earth Energy & Water</u> Certificate Number <u>153</u>			
				Address <u>New Salem ND</u>			
				Signed By <u>Dan Muehl</u> Date <u>5-18-22</u>			