



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

NOV 22 2022

DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name <u>Brody Brandt</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>1017 Elm Road - Hazen ND 58545</u>				ENTERED ON COMPUTER			
WELL LOCATION Sketch map location must agree with written location.				WATER LEVEL			
		County <u>McLean</u>		GPS <u>X</u>		Static Water Level (In Feet) Below Surface <u>37</u>	
		1/4 <u>Merced</u>		1/4		If Flowing, Closed-In Pressure In PSI	
		<u>47.30465° N</u>				GPM Flow Through Inch Pipe	
		Township <u>101.59893° W</u>		Range		Section	
PROPOSED USE <u>14408608 DAC</u>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				☐ Pump ☐ Bailer ☒ Other <u>Air</u>			
☐ Stock ☒ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After <u>120</u> Hrs. Pumping <u>12</u> GPM <u>400</u>			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary				Feet After Hrs. Pumping GPM			
☐ Bored ☐ Auger ☐ If Other, Specify				Feet After Hrs. Pumping GPM			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
Bacteriological Analysis? ☐ Yes ☒ No				From To			
If So, To What Laboratory Was It Sent?				<u>Top Soil</u> <u>0</u> <u>1</u>			
WELL CONSTRUCTION				<u>Sand & clay</u> <u>1</u> <u>20</u>			
Diameter Of Hole In Inches <u>12.5</u>		Depth In Feet <u>184</u>		<u>Till</u> <u>20</u> <u>83</u>			
Casing: ☐ Steel ☐ Plastic ☐ Concrete ☐ Other				<u>Coal</u> <u>83</u> <u>84</u>			
☐ Threaded ☐ Welded ☐ If Other, Specify				<u>Sandy grey clay</u> <u>84</u> <u>128</u>			
Pipe Weight	Diameter	From	To	<u>fine sand</u> <u>128</u> <u>138</u>			
<u>7.10</u> lb/ft	<u>8"</u> inches	<u>+2</u> feet	<u>144</u> feet	<u>Grey clay</u> <u>138</u> <u>142</u>			
				<u>Sand w/ coal streaks</u> <u>142</u> <u>180</u>			
				<u>Gravel & sand</u> <u>180</u> <u>190</u>			
				<u>Clay & gravel</u> <u>190</u> <u>195</u>			
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval		From In Feet	To In Feet				
Was Casing Left Open End? ☐ Yes ☒ No							
Material <u>PVC</u>		Diameter In Inches <u>8"</u>					
Slot Size <u>.032</u>	Set From In Feet <u>144</u>	To In Feet <u>184</u>		Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet		DATE COMPLETED <u>10-26-22</u>			
Was Packer Or Seal Used? ☐ Yes ☒ No				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
If So, What Material		Depth In Feet		If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				REMARKS			
Depth Grouted		From <u>0</u>	To <u>140</u>	<u>Owner to get water testing</u>			
Grouting Material		Cement	Other <u>X</u>				
If Other, Explain <u>Benbrink Grout & 3/8 Benbrink Chips</u>							
Well Head Completion: Pitless Unit <u>No</u>				DRILLER'S CERTIFICATION			
12" Above Grade		Other (Specify) <u>+24"</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>Depth Well Drilling</u> Certificate Number <u>188</u>			
				Address <u>PO Box 3100 - Minot ND 58702</u>			
				Signed By <u>Dan</u> Date <u>11-4-22</u>			