



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

NOV 29 2022

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☒ No			
Name <u>Wyatt Goheen</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>3925 27th St SE - Minot ND 58201</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface			
		County <u>Ward</u>		GPS ☒		If Flowing, Closed-In Pressure In PSI	
		1/4 <u>48.1933° N</u>		1/4		GPM Flow Through Inch Pipe	
		Township <u>101.24814° W</u>		Range		Section	
PROPOSED USE <u>15403a05BBD</u>				WELL TEST DATA			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				☒ Pump ☐ Bailer ☐ Other			
☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After <u>150</u> Hrs. Pumping <u>8</u> GPM <u>10</u>			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary				Feet After Hrs. Pumping GPM			
☐ Bored ☐ Auger ☐ If Other, Specify				Feet After Hrs. Pumping GPM			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
Bacteriological Analysis? ☐ Yes ☒ No				From To			
If So, To What Laboratory Was It Sent?				Top soil 0 2			
WELL CONSTRUCTION				Coarse sand & gravel 2 60			
Diameter Of Hole In Inches <u>9 7/8</u>		Depth In Feet <u>168</u>		Till 40 18			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other		☐ Threaded ☐ Welded ☐ If Other, Specify		Coarse Brown sand 18 27			
Pipe Weight	Diameter	From	To	Till 27 35			
lb/ft <u>2.9</u>	inches <u>5</u>	feet <u>+3</u>	feet <u>125</u>	Coal 35 36			
lb/ft	inches	feet	feet	Till 36 40			
lb/ft	inches	feet	feet	Rock 40 44			
Was A Well Screen Installed? ☒ Yes ☐ No				Sandy grey clay 44 75			
Was Perforated Pipe Used? ☐ Yes ☒ No				Gravel w/ coal streaks 75 82			
Screen Or Perforation Interval		From In Feet To In Feet		Coal 82 83			
Was Casing Left Open End? ☐ Yes ☒ No				Gravel 83 85			
Material <u>PVC</u>		Diameter In Inches <u>5</u>		Rock 85 87			
Slot Size <u>.025</u>		Set From In Feet <u>125</u>		Gravel 87 100			
Slot Size		To In Feet <u>165</u>		Gravel w/ coal streaks 100 122			
Was Packer Or Seal Used? ☐ Yes ☒ No				Coarse gravel w/ sand 122 144			
If So, What Material		Depth In Feet		Gravel, sand & blue clay 144 160			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				Brown clay w/ gravel 160 172			
Depth Grouted		From To		Use Separate Sheet If Necessary			
Grouting Material		Cement Other		DATE COMPLETED <u>10-16-22</u>			
If Other, Explain: <u>3/8 Bentonite chips w/ Bentonite grout</u>				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Well Head Completion: Pitless Unit <u>N/A</u>				If So, How			
12" Above Grade		Other (Specify) <u>+36"</u>		REMARKS			
It Other, Specify				Owner to get water tested.			
DRILLER'S CERTIFICATION				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Driller's Or Firm's Name <u>Depth Well Drilling</u>		Certificate Number <u>188</u>					
Address <u>PO Box 3100 - Minot ND 58202</u>							
Signed By <u>Dan</u>		Date <u>10-20-22</u>					