



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

NOV 24 2023

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER		Was Pump Installed? ☐ Yes ☒ No <i>future solar</i>													
Name <i>U.S. Forest Service</i>		Was Well Disinfected Upon Completion? ☒ Yes ☐ No													
Address <i>1601 Main St Bismarck ND 58504</i>		WATER LEVEL													
WELL LOCATION Sketch map location must agree with written location.		Static Water Level (In Feet) Below Surface <i>11</i>													
<table border="1"><tr><td colspan="2">County <i>Ransom</i></td><td colspan="2">GPS</td></tr><tr><td>1/4 <i>NW</i></td><td>1/4 <i>SW</i></td><td colspan="2">1/4 <i>NE</i></td></tr><tr><td colspan="2">Township <i>134N</i></td><td>Range <i>52W</i></td><td>Section <i>8</i></td></tr></table>		County <i>Ransom</i>		GPS		1/4 <i>NW</i>	1/4 <i>SW</i>	1/4 <i>NE</i>		Township <i>134N</i>		Range <i>52W</i>	Section <i>8</i>	If Flowing, Closed-In Pressure In PSI	
County <i>Ransom</i>		GPS													
1/4 <i>NW</i>	1/4 <i>SW</i>	1/4 <i>NE</i>													
Township <i>134N</i>		Range <i>52W</i>	Section <i>8</i>												
		GPM Flow Through Inch Pipe													
		Controlled By ☐ Valve ☐ Reducers ☐ Other													
		☐ If Other, Specify													
PROPOSED USE <i>13405208ACB</i>		WELL TEST DATA													
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial		☒ Pump ☐ Bailer ☐ Other													
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole		Pumping Level Below Land Surface													
METHOD DRILLED		Feet After <i>20</i> Hrs. Pumping <i>2</i> GPM <i>20</i>													
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary		Feet After Hrs. Pumping GPM													
☐ Bored ☐ Auger ☐ If Other, Specify		Feet After Hrs. Pumping GPM													
WATER QUALITY Was a water sample collected for		WELL LOG													
Chemical Analysis? ☐ Yes ☒ No		Formation Depth (ft.)													
Bacteriological Analysis? ☐ Yes ☒ No		From To													
If So, To What Laboratory Was It Sent?		<i>Brown sand 0 7</i>													
WELL CONSTRUCTION		<i>silty sand 7 18</i>													
Diameter Of Hole In Inches <i>7 1/2</i> Depth In Feet <i>87'</i>		<i>Clean fine sand 18 87</i>													
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other															
☐ Threaded ☐ Welded ☐ If Other, Specify															
Pipe Weight <i>220</i> lb/ft	Diameter <i>58</i> inches	From <i>58</i> feet	To <i>+ 2</i> feet												
lb/ft	inches	feet	feet												
lb/ft	inches	feet	feet												
Was A Well Screen Installed? ☒ Yes ☐ No															
Was Perforated Pipe Used? ☐ Yes ☒ No															
Screen Or Perforation Interval	From In Feet <i>87</i>	To In Feet <i>77</i>													
Was Casing Left Open End? ☐ Yes ☒ No															
Material <i>PVC</i>	Diameter In inches <i>4</i>														
Slot Size <i>15</i>	Set From In Feet <i>87</i>	To In Feet <i>77</i>													
Slot Size	Set From In Feet	To In Feet													
Was Packer Or Seal Used? ☐ Yes ☒ No		Use Separate Sheet If Necessary													
If So, What Material		DATE COMPLETED <i>10/24/23</i>													
Depth In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No													
Type Of Well ☐ Straight Screen ☒ Gravel Packed		If So, How													
Depth Grouted From <i>77</i> To <i>57</i>		REMARKS													
Grouting Material <i>Cement</i> <i>Bentonite</i>		<i>perused O.K</i>													
If Other, Explain:		DRILLER'S CERTIFICATION													
Well Head Completion: Pitless Unit <i>well seal</i>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.													
12" Above Grade		Driller's Or Firm's Name <i>Sto Swandal / Andy Stokely</i> Certificate Number <i># 109</i>													
It Other, Specify		Address <i>Walcott ND</i>													
		Signed By <i>K. St. Swandal</i> Date <i>11/20/23</i>													