



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

FEB 21 2024

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Allan Slater</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>Hettinger ND</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>136 ft.</u>			
		County <u>Adams</u>		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4 <u>SE</u>	1/4 <u>NE</u>				
		Township <u>130</u>	Range <u>95</u>	Section <u>11</u>			
PROPOSED USE <u>13009511AD</u>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <u>196</u> Hrs. Pumping <u>2</u> GPM <u>12</u>			
WATER QUALITY Was a water sample collected for				Feet After _____ Hrs. Pumping _____ GPM _____			
Chemical Analysis? ☐ Yes ☒ No				WELL LOG			
Bacteriological Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
If So, To What Laboratory Was It Sent?				From To			
WELL CONSTRUCTION				Top Soil 0 2			
Diameter Of Hole In Inches <u>7 7/8</u>		Depth In Feet <u>255</u>		Sand Gravel 2 8			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other				Sandy Gray Clay 8 30			
☐ Threaded ☒ Welded ☐ If Other, Specify _____				Fine Gray Sand 30 75			
Pipe Weight	Diameter	From	To	Gray Clay 75 85			
lb/ft <u>509.21</u>	inches <u>4</u>	feet <u>0</u>	feet <u>255</u>	Fine Gray Sand 85 90			
lb/ft	inches	feet	feet	Sandy Gray Clay 90 110			
lb/ft	inches	feet	feet	Rock ledge 110 113			
Was A Well Screen Installed? ☒ Yes ☐ No				Gray Clay 113 147			
Was Perforated Pipe Used? ☒ Yes ☐ No				Rock ledge 147 148			
Screen Or Perforation Interval	From In Feet	To In Feet		Gray Clay 148 196			
	<u>225</u>	<u>258</u>		Rock ledge 196 197			
Was Casing Left Open End? ☐ Yes ☒ No				Med. Blue Sand 197 200			
Material <u>Pvc</u>	Diameter In Inches <u>4</u>			Clay Sand Strainers 200 228			
Slot Size <u>16</u>	Set From In Feet <u>225</u>	To In Feet <u>255</u>		Med. Blue Sand 228 245			
Slot Size	Set From In Feet	To In Feet		Rock ledge 245 247			
Was Packer Or Seal Used? ☐ Yes ☒ No				Med. Blue Sand 247 260			
If So, What Material				Hard Brown Clay 260 270			
Depth In Feet				Use Separate Sheet If Necessary			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				DATE COMPLETED <u>19-25-23</u>			
Depth Grouted <u>25-205</u>	From <u>30-8</u>	To		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Grouting Material <u>Cement</u>	Cement		Other <u>X</u>	If So, How			
If Other, Explain: <u>BE-IT CHIPS</u>				REMARKS			
Well Head Completion: Pitless Unit <u>YES</u>				DRILLER'S CERTIFICATION			
12" Above Grade <u>YES</u>				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>EEWS, Inc.</u> Certificate Number <u>563</u>			
				Address <u>New Salem ND</u>			
				Signed By <u>[Signature]</u> Date <u>12-8-23</u>			