



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

SEP 17 2024

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850 ND DEPT. OF WATER RESOURCES
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER		Was Pump Installed? ☒ Yes ☐ No	
Name <u>Bryan Nohava</u>		Was Well Disinfected Upon Completion? ☒ Yes ☐ No	
Address <u>16330 59th St. SE Wacota, ND 58077</u>		WATER LEVEL	
WELL LOCATION Sketch map location must agree with written location.		Static Water Level (In Feet) Below Surface <u>8</u>	
	County <u>Richland</u>	GPS	
	1/4 <u>NW</u>	1/4 <u>NE</u>	1/4 <u>NW</u>
	Township <u>136</u>	Range <u>50</u>	Section <u>32</u>
	If Flowing, Closed-In Pressure In PSI		
GPM Flow		Through	Inch Pipe
Controlled By ☐ Valve ☐ Reducers ☐ Other		☐ If Other, Specify _____	
PROPOSED USE <u>13605032BAB</u>		WELL TEST DATA	
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial		☐ Pump ☐ Bailer ☒ Other	
☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole		Pumping Level Below Land Surface	
METHOD DRILLED		Feet After	Hrs. Pumping
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary		<u>60</u>	<u>4</u>
☐ Bored ☐ Auger ☐ If Other, Specify _____		Feet After	GPM
WATER QUALITY Was a water sample collected for			<u>25</u>
Chemical Analysis? ☐ Yes ☐ No			GPM
Bacteriological Analysis? ☐ Yes ☐ No			
If So, To What Laboratory Was It Sent?			
WELL CONSTRUCTION		Feet After	Hrs. Pumping
Diameter Of Hole In Inches <u>6 1/4</u>	Depth In Feet <u>90</u>		GPM
Casing:			
☐ Steel ☒ Plastic ☐ Concrete ☐ Other			
☐ Threaded ☒ Welded ☐ If Other, Specify _____			
Pipe Weight	Diameter	From	To
lb/ft	inches	feet	feet
<u>1.94</u>	<u>4</u>	<u>0</u>	<u>82</u>
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet
Was A Well Screen Installed? ☒ Yes ☐ No			
Was Perforated Pipe Used? ☐ Yes ☒ No			
Screen Or Perforation Interval	From In Feet	To In Feet	
Was Casing Left Open End? ☐ Yes ☒ No			
Material <u>Stainless Steel</u>	Diameter In Inches <u>3"</u>		
Slot Size <u>.010</u>	Set From In Feet <u>82</u>	To In Feet <u>90</u>	
Slot Size	Set From In Feet	To In Feet	
Was Packer Or Seal Used? ☐ Yes ☒ No			
If So, What Material	Depth In Feet		
Type Of Well ☐ Straight Screen ☒ Gravel Packed			
Depth Grouted	From	To	
	<u>0</u>	<u>50</u>	
Grouting Material	Cement	Other	
		<u>Bentonite</u>	
If Other, Explain:			
Well Head Completion: Pitless Unit <u>4 x 5 mon</u>		DRILLER'S CERTIFICATION	
12" Above Grade	Other (Specify)	This well was drilled under my jurisdiction and this report is true to the best of my knowledge.	
It Other, Specify		Driller's Or Firm's Name	Certificate Number
		<u>L.T.P. Enterprises, Inc.</u>	<u>136</u>
		Address	
		<u>P.O. Box 9035 Fargo ND 58106</u>	
		Signed By	Date
		<u>Chris Hannum</u>	<u>9/19/24</u>