




WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

OCT 21 2024

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

ND DEPT. OF WATER

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name SHAY LATENDRESSE				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 206 71st ST N, TOWNER, ND 58788				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 14			
		County McHENRY		GPS SEE REMARKS		If Flowing, Closed-In Pressure In PSI	
		1/4 NE		1/4		GPM Flow Through Inch Pipe	
		Township 157		Range 77		Section 12	
PROPOSED USE 15707712ADB				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other AIR LIFT			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After 0 Hrs. Pumping 1 hours GPM 3-4			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent? BY OWNER				Formation Depth (ft.) From To			
WELL CONSTRUCTION				DRIFT SAND 0 8			
Diameter Of Hole In Inches 9" Depth In Feet 96				SANDY CLAY 8 12			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				CLAY 12 28			
Pipe Weight Diameter From To				SANDY FINE W/ CLAY 28 39			
lb/ft inches feet feet				CLAY 39 84			
SDR 21 5 0 96				CLAY W/ SAND LAYERS 84 91			
lb/ft inches feet feet				SAND 91 95			
lb/ft inches feet feet				CLAY 95 140			
Was A Well Screen Installed? ☐ Yes ☒ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval From In Feet To In Feet							
Was Casing Left Open End? ☐ Yes ☒ No							
Material Slotted Plastic Diameter In Inches 5				Use Separate Sheet If Necessary			
Slot Size .025" Set From In Feet 83 To In Feet 96				DATE COMPLETED 09/10/24			
Slot Size Set From In Feet To In Feet				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☐ Yes ☒ No				If So, How			
If So, What Material Depth In Feet				REMARKS			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				Lat/lon: 48.439840 / -100.540423			
Depth Grouted From 0' To 20'							
Grouting Material BENTONITE CHIPS Cement Other							
If Other, Explain:				DRILLER'S CERTIFICATION			
Well Head Completion: Pitless Unit NO				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
12" Above Grade YES Other (Specify)				Driller's Or Firm's Name ERCK WELL DRILLING, INC. Certificate Number 147			
If Other, Specify				Address PO BOX 307 MINOT ND 58701			
				Signed By [Signature] Date 09/10/24			

COPY FOR BOARD

COPY FOR DRILLER

COPY FOR CUSTOMER