



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

OCT 21 2024

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

ND DEPT. OF WATER RESOURCES

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name DAVID WOODALL				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 6480 15 AVE N, GRANVILLE, ND 58741				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 7			
		County McHENRY		GPS SEE REMARKS		If Flowing, Closed-In Pressure In PSI	
		1/4 NW	1/4 NW	1/4 SW	GPM Flow Through Inch Pipe		
		Township 157	Range 79	Section 17	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____		
					WELL TEST DATA		
PROPOSED USE 15707917CBB				☐ Pump ☐ Bailer ☒ Other AIR LIFT			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After Hrs. Pumping GPM			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				60 1 hours 6-8			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent? BY OWNER				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches 9"		Depth In Feet 98		FINE SAND		0 11	
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				CLAY		11 51	
Pipe Weight	Diameter	From	To	FINE SAND		51 54	
lb/ft	inches	feet	feet	CLAY		54 72	
SDR 21	5	0	98	CLAY W/ SAND LAYERS		72 97	
lb/ft	inches	feet	feet	CLAY		97	
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☐ Yes ☒ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval		From In Feet	To In Feet				
Was Casing Left Open End? ☐ Yes ☒ No							
Material SLOTTED PLASTIC		Diameter In Inches 5		Use Separate Sheet If Necessary			
Slot Size .025"	Set From In Feet 68	To In Feet 98		DATE COMPLETED 08/28/24			
Slot Size	Set From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☐ Yes ☒ No				If So, How			
If So, What Material		Depth In Feet		REMARKS			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				Lat/lon: 48.422139 / -100.907116			
Depth Grouted		From 0'	To 20'				
Grouting Material BENTONITE CHIPS		Cement Other					
If Other, Explain:							
Well Head Completion: Pitless Unit NO				DRILLER'S CERTIFICATION			
12" Above Grade YES		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
If Other, Specify				Driller's Or Firm's Name ERCK WELL DRILLING, INC.		Certificate Number 147	
				Address PO BOX, 307, MINOT ND 58701			
				Signed By 		Date 08/28/24	

COPY FOR BOARD

COPY FOR DRILLER

COPY FOR CUSTOMER