

RECEIVED

OCT 21 2024

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name DUAINE PATTERSON				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 1636 59th ST N, NORWICH, ND 58768				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 5			
		County McHENRY		GPS SEE REMARKS		If Flowing, Closed-In Pressure In PSI	
		1/4 SE	1/4 E	1/4 SW	GPM Flow Through Inch Pipe		
		Township 158	Range 79	Section 29	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____		
PROPOSED USE 15807929DCD				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other AIR LIFT			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After 55 Hrs. Pumping 1 hours GPM 7-8 Feet After Hrs. Pumping GPM Feet After Hrs. Pumping GPM			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☒ No				Formation			
Bacteriological Analysis? ☐ Yes ☒ No				Depth (ft.) From To			
If So, To What Laboratory Was It Sent? BY OWNER				DRIFT SAND 0 5			
WELL CONSTRUCTION				CLAY 5 12			
Diameter Of Hole In Inches 9"		Depth In Feet 151		SAND 12 13			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				CLAY 13 41			
Pipe Weight	Diameter	From	To	SAND 41 42			
lb/ft SDR 21	inches 5	feet 0	feet 151	CLAY W/ SAND STREAKS 57', 70' 42 135			
lb/ft	inches	feet	feet	BLUE SAND 135 151			
lb/ft	inches	feet	feet	CLAY 151			
Was A Well Screen Installed? ☐ Yes ☒ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
Was Casing Left Open End? ☐ Yes ☒ No							
Material SLOTTED PLASTIC		Diameter In Inches 5		Use Separate Sheet If Necessary			
Slot Size .025"	Set From In Feet 131	To In Feet 151		DATE COMPLETED 08/22/24			
Slot Size	Set From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☐ Yes ☒ No				If So, How			
If So, What Material		Depth In Feet		REMARKS			
Type Of Well	☐ Straight Screen ☒ Gravel Packed			Lat/Lon: 48.473430 / -100.893758			
Depth Grouted	From 0'	To 20'					
Grouting Material BENTONITE CHIPS	Cement	Other					
If Other, Explain:							
Well Head Completion: Pitless Unit NO				DRILLER'S CERTIFICATION			
12" Above Grade YES	Other (Specify)			This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name ERCK WELL DRILLING, INC.			
				Certificate Number 147			
				Address PO BOX, 307 MINOT ND 58701			
				Signed By <i>[Signature]</i>			
				Date 08/22/24			

COPY FOR BOARD

COPY FOR DRILLER

COPY FOR CUSTOMER