



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

NOV - 8 2024

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☐ No			
Name MATT GUTHMILLER				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 4627 25th St SE - Pettibone ND				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 9'6" TOP OF CASING			
		County STUTSMAN		GPS E.L. 1765		If Flowing, Closed-In Pressure In PSI	
		1/4 NE	1/4 SW	1/4 SW			
		Township 47° 02' 30" N		Range 99° 28' 37" W		Section 141 155 69 50 7	
PROPOSED USE 14106907CCA				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☒ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☐ Forward Rotary ☒ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After Hrs. Pumping GPM 12" 1 100			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No by DWL/EA				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.) From To			
WELL CONSTRUCTION				clay - sandy loam 0 6			
Diameter Of Hole In Inches 26		Depth In Feet 54		large gravel - small pack 6 11			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				sand + gravel - green tint 11 20			
Pipe Weight	Diameter	From	To	sand + gravel coarse smooth 20 52			
lb/ft	inches	feet	feet	clay - gray 52 54			
SDR 21	12	2 above	13				
lb/ft	inches	feet	feet				
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☐ Yes ☒ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
	14	54					
Was Casing Left Open End? ☒ Yes ☐ No							
Material		Diameter In Inches					
				Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet		DATE COMPLETED 10/15/24			
0032	14	54		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Slot Size	Set From In Feet	To In Feet		If So, How			
				REMARKS			
Was Packer Or Seal Used? ☐ Yes ☒ No				estimated 800 GPM to 10' draw down 90 GPM / ft draw down			
If So, What Material		Depth In Feet		DRILLER'S CERTIFICATION			
				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				Driller's Or Firm's Name		Certificate Number	
Depth Grouted		From	To	Terry Kemmer		81	
Grouting Material		Cement	Other	Address			
			clay chips	Tappen			
If Other, Explain:				Signed By		Date	
Well Head Completion: Pitless Unit				Terry Kemmer		10/19/24	
12" Above Grade		Other (Specify)					
X							
It Other, Specify							