



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

NOV - 8 2024

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☐ No			
Name Michael BERG XMAS ACRES				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 216 FIRST AVE SE. TAPPEN ND.				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 9.5'			
County Kidder GPS ELEV 1774' 1/4 46° NE 1/4 51' NW 1/4 23" N SW Township 99° Range 41 Section 15				If Flowing, Closed-In Pressure In PSI			
				GPM Flow Through Inch Pipe			
				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
PROPOSED USE 13907115CBA				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☒ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☐ Forward Rotary ☒ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After Hrs. Pumping GPM 2.5 1 90			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent? by owner				Formation Depth (ft.) From To			
WELL CONSTRUCTION				topsoil black 0 3			
Diameter Of Hole In Inches 26		Depth In Feet 94		sand brown medium 3 10			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				sand fine dark 10 38			
Pipe Weight	Diameter	From	To	wood shavings - seashells - coal 38 40			
lb/ft	inches	feet	feet	sand - dark med 40 60			
50021	12	2 APPROX		sand - dark coarse with shale 5% 60 95			
lb/ft	inches	feet	feet				
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
	54	94					
Was Casing Left Open End? ☐ Yes ☒ No							
Material PVC		Diameter In Inches					
Slot Size	Set From In Feet	To In Feet		Use Separate Sheet If Necessary			
P32	54	94					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No				DATE COMPLETED 10/25/2024			
If So, What Material		Depth In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
				If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				REMARKS			
Depth Grouted	From	To		well drawdown is 35 gpm/ft			
	0	20					
Grouting Material	Cement	Other					
		clay chips					
If Other, Explain:							
Well Head Completion: Pitless Unit				DRILLER'S CERTIFICATION			
12" Above Grade		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
X				Driller's Or Firm's Name		Certificate Number	
				Terry Kammert		81	
It Other, Specify				Address			
				Tappen			
				Signed By		Date	
				Terry Kammert		NOV 5 2024	