



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

NOV - 8 2024

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND 58005-0550
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <i>Mark Rau</i>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <i>3643 58th St NE Napoleon ND</i>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>145'</i>			
		County <i>Langan</i>		GPS <i>el-2061</i>		If Flowing, Closed-In Pressure In PSI	
		1/4 <i>NE</i>	1/4 <i>NE</i>	1/4 <i>SW</i>	GPM Flow Through Inch Pipe		
		Township <i>46° 35' 59" N</i>		Range <i>99° 37' 59" W</i>		Section	
PROPOSED USE <i>13607129 BDD</i>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other <i>air</i>			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After Hrs. Pumping GPM <i>170 1 10</i>			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent? <i>by owner</i>				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches <i>7"</i>		Depth In Feet <i>225'</i>		<i>topsoil - rocky 0 2</i>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				<i>sandy clay broken 2 60</i>			
Pipe Weight	Diameter	From	To	<i>sandy fine salty dirt 60 110</i>			
<i>508 21</i>	<i>4</i>	<i>2</i>	<i>205</i>	<i>clay - gray 110 200</i>			
lb/ft	inches	feet	feet	<i>sand - fine-medium dirt 200 225</i>			
lb/ft	inches	feet	feet				
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☐ Yes ☐ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
	<i>205</i>	<i>225</i>					
Was Casing Left Open End? ☐ Yes ☒ No							
Material		Diameter In Inches		Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet					
<i>.016</i>	<i>205</i>	<i>225</i>					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No				DATE COMPLETED <i>Sept 10</i>			
If So, What Material		Depth In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
				If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				REMARKS			
Depth Grouted	From	To					
<i>30</i>	<i>0</i>	<i>30</i>					
Grouting Material	Cement	Other					
<i>chips</i>							
If Other, Explain:							
Well Head Completion: Pitless Unit				DRILLER'S CERTIFICATION			
12" Above Grade <i>x</i>		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <i>Terry Kennet</i>		Certificate Number <i>81</i>	
				Address <i>Langan ND 58437</i>			
				Signed By <i>Terry Kennet</i>		Date <i>10/18/24</i>	